

RFI FORM

Contractor Name:

Address:

Phone/Fax:

send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	003
PROJECT NAME:	REMEDiate Water Intrusion Damage	DATE REQUESTED:	01/25/2017
SOLICITATION NO.:	VA262-17-Q-0293	REFERENCE:	Seismic Requirements
DRAWING:	N/A	SPECIFICATION SECTION:	N/A
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Will the VA require any seismic retrofits or upgrades for the relatively small portion of cast iron drain pipe being replaced?			
PROJECT MANAGER'S RESPONSE			
NO seismic retrofits or upgrades are required for the portion being replaced.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: TIM CONROY		DATE: 1/25.2017	