



- ### Key Notes
- 1 TYPICAL EXISTING RECESSED DOWN LIGHTING, EXIT SIGN FIXTURES, DUPLEX RECEPTACLES AND FIRE ALARM DEVICES SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED TO SOURCE.
  - 2 TYPICAL EXISTING CARD READER SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED TO SOURCE.
  - 3 TYPICAL EXISTING SURFACE MOUNTED FLUORESCENT FIXTURE MOUNTED UNDER PASSAGE CORRIDOR IN SECOND FLOOR MECHANICAL ROOM SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED TO SOURCE.
  - 4 EXISTING PANELBOARD W2D2 SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED. SEE RISER DIAGRAM ON SHEET EPS-101.
  - 5 EXISTING PANELBOARD W2D1 SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED. SEE RISER DIAGRAM ON SHEET EPS-101.
  - 6 EXISTING PANELBOARD W2E SHALL BE DE-ENERGIZED, DISCONNECTED AND REMOVED. SEE RISER DIAGRAM ON SHEET EPS-101.
  - 7 EXISTING DATA CABLES SERVING EXISTING LAB ARE TO BE DE-ENERGIZED, DISCONNECTED AND REMOVED BACK TO EXISTING IT CLOSET.
  - 8 EXISTING 3/4" EMT CONDUIT WITH 6 #12 AWG CONDUCTOR SHALL BE RELOCATED TO NEW CHASE. SEE DRAWING EP1-101 FOR ADDITIONAL INFORMATION.
  - 9 EXISTING STAIRWELL PAGING SPEAKER TO BE RELOCATED.
  - 10 CABINET HEATER TO BE DE-ENERGIZED AND DISCONNECTED. EXTEND EXISTING 120 VOLT 20 AMP CIRCUIT TO NEW HEATER.

**GENERAL NOTE:**  
ELECTRICAL CONTRACTOR SHALL REMOVE ALL ABANDONED RACEWAYS NO LONGER BEING USED BACK TO THE PANELBOARD.

three inches = one foot  
 one and one half inches = one foot  
 one inch = one foot  
 three eighths inch = one foot  
 one half inch = one foot  
 three eighths inch = one foot  
 one eighth inch = one foot  
 one quarter inch = one foot  
 one eighth inch = one foot

1 ELECTRICAL DEMO BRIDGE LEVEL  
1/8" = 1'-0"

PEER REVIEW DOCUMENTS - DECEMBER 21st, 2016

FULLY SPRINKLERED

Revisions:	Date
1 AMENDMENT 3	01-31-17

**CONSULTANTS:**

**ARCHITECT/ENGINEERS:**

ARCHITECTURE  
 ENGINEERING  
 INTERIOR DESIGN  
 DESIGN/BUILD  
**ASTORINO**

227 Fort Pitt Boulevard Pittsburgh, Pennsylvania 15222  
 TEL 412 765 1700 FAX 412 765 1711 www.astorino.com

Drawing Title  
**ELECTRICAL DEMOLITION PLAN**

Approved: Project Director

Project Title  
**VA CARES CONSOLIDATION VAMC, PITTSBURGH, PA CONNECTING BRIDGE**

Project Number  
**646CA2500B**

Building Number  
**1 & 30**

Location  
**VAPHS UNIVERSITY DRIVE**

Drawing Number  
**ESD-801**

Dwg. of

**Office of Facilities Management**

**Department of Veterans Affairs**