

three inches = one foot
 one and one half inches = one foot
 one inch = one foot
 three eighths inch = one foot
 one half inch = one foot
 one quarter inch = one foot
 three eighths inch = one foot
 one eighth inch = one foot

Branch Panel: W2D2

LOCATION: 2ND FL BLDG 1
 SUPPLY FROM: W2D1
 MOUNTING: SURFACE
 ENCLOSURE: NEMA 1

VOLTS: 208/120V
 PHASES: 3
 WIRES: 4

A.I.C. Rating: 10,000
 Mains Type: MCB
 Mains Rating: 225A
 MCB Rating: ---

NOTES:

CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	C	POLES	TRIP	CIRCUIT DESCRIPTION	CKT	
1	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	2	
3	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	4	
5	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	6
7	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	8	
9	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	10	
11	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	12
13	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	14	
15	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	16	
17	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	18
19	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	20	
21	REC - CORRIDOR	20 A	1		.6	1.2	1	20 A	REC - LAB	22	
23	REC - LAB	20 A	1			.8	1.2	1	20 A	REC - LAB	24
25	REC - LAB	20 A	1	1.2	---		1	20 A	SPARE	26	
27	SPARE	20 A	1	---	---	---	1	20 A	SPARE	28	
29	SPARE	20 A	1	---	---	---	1	20 A	SPARE	30	
31	SPARE	20 A	1	---	---	---	1	20 A	SPARE	32	
33	SPARE	20 A	1	---	---	---	1	20 A	SPARE	34	
35	SPARE	20 A	1	---	---	---	1	20 A	SPARE	36	
37	SPARE	20 A	1	---	---	---	1	20 A	SPARE	38	
39	SPARE	20 A	1	---	---	---	1	20 A	SPARE	40	
41	SPARE	20 A	1	---	---	---	1	20 A	SPARE	42	

TOTAL LOAD: 7.6 6.6 6.8
 TOTAL LOAD: 21 KVA

Branch Panel: W2D1

LOCATION: 2ND FL BLDG 1
 SUPPLY FROM: DPW2
 MOUNTING: SURFACE
 ENCLOSURE: NEMA 1

VOLTS: 208/120V
 PHASES: 3
 WIRES: 4

A.I.C. Rating: 10,000
 Mains Type: MCB
 Mains Rating: 225A
 MCB Rating: 225A-3P

NOTES: FEED THRU LUGS

CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	C	POLES	TRIP	CIRCUIT DESCRIPTION	CKT	
1	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	2	
3	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	4	
5	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	6
7	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	8	
9	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	10	
11	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	12
13	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	14	
15	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	16	
17	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	18
19	EXISTING LOADS	20 A	1	.8	.8		1	20 A	EXISTING LOADS	20	
21	EXISTING LOADS	20 A	1		.8	.8	1	20 A	EXISTING LOADS	22	
23	EXISTING LOADS	20 A	1			.8	.8	1	20 A	EXISTING LOADS	24
25	EXISTING LOADS	20 A	1	.8	1.5		2	30 A	EXISTING LOADS	26	
27	EXISTING LOADS	20 A	1		.8	1.5	---	---	---	28	
29	EXISTING LOADS	15 A	2			.8	2.0	1	40 A	EXISTING LOADS	30
31	---	---	---	.8	2.0		---	---	---	32	
33	EXISTING LOADS	20 A	2		1.0	2.5	2	50 A	EXISTING LOADS	34	
35	---	---	---	---	---	1.0	2.5	---	---	36	
37	EXISTING LOADS	30 A	3	2.5	2.5		3	30 A	EXISTING LOADS	38	
39	---	---	---	---	---	2.5	2.5	---	---	40	
41	---	---	---	---	---	2.5	2.5	---	---	42	

TOTAL LOAD: 16.5 17.2 17.7
 TOTAL LOAD: 51.4 KVA

Branch Panel: W2E

LOCATION: 2ND FL BLDG 1
 SUPPLY FROM: DPW2
 MOUNTING: SURFACE
 ENCLOSURE: NEMA 1


VOLTS: 208/120V
 PHASES: 3
 WIRES: 4

A.I.C. Rating: 10,000
 Mains Type: MCB
 Mains Rating: 225A
 MCB Rating: 225A-3P

NOTES:

CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	C	POLES	TRIP	CIRCUIT DESCRIPTION	CKT	
1	EXISTING LOADS	20 A	1	0.8	0.8		1	20 A	EXISTING LOADS	2	
3	EXISTING LOADS	20 A	1		0.8	0.8	1	20 A	EXISTING LOADS	4	
5	EXISTING LOADS	20 A	1			0.8	0.8	1	20 A	EXISTING LOADS	6
7	EXISTING LOADS	20 A	1	0.8	0.8		1	20 A	EXISTING LOADS	8	
9	EXISTING LOADS	20 A	1		0.8	0.8	1	20 A	EXISTING LOADS	10	
11	EXISTING LOADS	20 A	1			0.8	0.8	1	20 A	EXISTING LOADS	12
13	EXISTING LOADS	20 A	1	0.8	0.8		1	20 A	EXISTING LOADS	14	
15	EXISTING LOADS	20 A	1		0.8	0.8	1	20 A	EXISTING LOADS	16	
17	EXISTING LOADS	20 A	1			0.8	0.8	1	20 A	EXISTING LOADS	18
19	EXISTING LOADS	20 A	1	0.8	0.8		1	20 A	EXISTING LOADS	20	
21	EXISTING LOADS	20 A	1		0.8	0.8	1	20 A	EXISTING LOADS	22	
23	SPARE	20 A	1	---	---	---	1	20 A	SPARE	24	
25	SPARE	20 A	1	---	---	---	1	20 A	SPARE	26	
27	SPARE	20 A	1	---	---	---	1	20 A	SPARE	28	
29	SPARE	20 A	1	---	---	---	1	20 A	SPARE	30	
31	SPARE	20 A	1	---	---	---	1	20 A	SPARE	32	
33	SPARE	20 A	1	---	---	---	1	20 A	SPARE	34	
35	SPARE	20 A	1	---	---	---	1	20 A	SPARE	36	
37	SPARE	20 A	1	---	7.2	---	3	70 A	EXISTING PANELBOARD WZF	38	
39	EXISTING LOADS	20 A	2		1.0	7.2	---	---	---	40	
41	---	---	---	---	---	1.0	7.2	---	---	42	

TOTAL LOAD: 13.6 14.6 13
 TOTAL LOAD: 41.2 KVA



PEER REVIEW DOCUMENTS - DECEMBER 21st, 2016
 FULLY SPRINKLERED

CONSULTANTS: 	ARCHITECT/ENGINEERS: ARCHITECTURE ENGINEERING INTERIOR DESIGN DESIGN/BUILD ASTORINO 227 Fort Pitt Boulevard Pittsburgh, Pennsylvania 15222 TEL 412 765 1700 FAX 412 765 1711 www.astorino.com	Drawing Title PANELBOARD SCHEDULES	Project Title VA CARES CONSOLIDATION VAMC, PITTSBURGH, PA CONNECTING BRIDGE	Project Number 646CA2500B	Office of Facilities Management Department of Veterans Affairs
		Approved: Project Director	Location VAPHS UNIVERSITY DRIVE	Building Number 1 & 30	
1 AMENDMENT 3 Revisions:	01-31-17 Date	Date Checked Drawn Checker Author	Date Checked Drawn Checker Author	Dwg. of	