


- ### Key Notes
- 1 POWER DOOR WITH CARD READER
 - 2 NEW PANELBOARD W2D2 - 208/120V 30 4W.
 - 3 NEW PANELBOARD W2D1 - 208/120V 30 4W.
 - 4 NEW PANELBOARD W2E - 208/120V 30 4W.
 - 5 RELOCATED 3/4" EMT CONDUIT WITH 6 #12 AWG CONDUCTORS PROVIDE JUNCTION BOXES AND ALL WIRING/RACEWAY MODIFICATIONS AS REQUIRED. COORDINATE RELOCATON AND CIRCUIT OUTRAGE WITH OWNER.
 - 6 TO EXISTING PANELBOARD LS2LA. CIRCUIT #38 LOCATED APPROX 300' AWAY ON THE SECOND FLOOR OF BUILDING 30. PROVIDE #10 AWG WIRE TO COMPENSATE FOR VOLTAGE DROP.
 - 7 TO EXISTING PANELBOARD 2LC. CIRCUIT #42 LOCATED APPROX. 100' AWAY ON THE SECOND FLOOR OF BUILDING 30.
 - 8 FLOOR IN THIS AREA IS RAISED 14" AND IS TO RAMP DOWN TO THE RIGHT. ALL NEW AND EXISTING ELECTRICAL SERVICES SHALL BE COORDINATED WITH ALL OTHER TRADES TO MAINTAIN REQUIRED CEILING HEIGHT.
 - 9 HANDS FREE DOOR ACTUATOR EMPTY RACEWAY SYSTEM.
 - 10 EXISTING CABINET HEATER TO BE REPLACED WITH NEW. INTERCEPT EXISTING 120V 20AMP CIRCUIT CURRENTLY SERVING UNIT AND EXTEND TO NEW UNIT AS REQUIRED.
 - 11 TO EXISTING 120 VOLT, 20 AMP EMERGENCY CIRCUIT IN BUILDING 1.
 - 12 PA AMPLIFIER. TO 120 VOLT, 20 AMP EMERGENCY CIRCUIT.
 - 13 TO 120 VOLT, 20 AMP EMERGENCY LIFE SAFETY CIRCUIT.



PEER REVIEW DOCUMENTS - DECEMBER 21st, 2016

FULLY SPRINKLERED

EP1-101_1
1/8" = 1'-0"

Revisions:	Date
1 AMENDMENT 3	01-31-17

VA FORM 08-6231, OCT 1978

CONSULTANTS:

ARCHITECT/ENGINEERS:

ARCHITECTURE
ENGINEERING
INTERIOR DESIGN
DESIGN/BUILD

ASTORINO

227 Fort Pitt Boulevard Pittsburgh, Pennsylvania 15222
TEL 412 765 1700 FAX 412 765 1711 www.astorino.com

Drawing Title
BRIDGE POWER PLAN

Approved: Project Director

Project Title
**VA CARES CONSOLIDATION
VAMC, PITTSBURGH, PA
CONNECTING BRIDGE**

Project Number
646CA2500B

Building Number
1 & 30

Location
VAPHS UNIVERSITY DRIVE

Drawing Number
EP1-101

Date: _____
Checked: _____
Drawn: _____
Checker: _____
Author: _____

Dwg. of _____

**Office of
Facilities
Management**

**Department of
Veterans Affairs**