




1. DETAILS SHOWN ARE TYPICAL, AND BASED ON AS-BUILT DRAWINGS AND TYPICAL ASC EQUIPMENT. THIS DIAGRAM IS FOR REFERENCE ONLY.
2. THE CONTRACTOR SHALL FIELD VERIFY ACTUAL EXISTING POWER AND CONTROL CABLE LENGTHS PRIOR TO BEGINNING SWITCH CHANGE-OUT. IF EXISTING LENGTHS ARE NOT ADEQUATE, CONTACT ARCHITECT AND ENGINEER PRIOR TO BEGINNING ANY WORK.
3. FIELD VERIFY EXACT LOCATIONS OF ALL EQUIPMENT.
4. RECONNECT ALL CONTROL WIRING AT ATS'S AS SHOWN ON "ES" SHEETS.
5. THE DIAGRAM IS FOR REFERENCE ONLY UON.

		APPROVED BY:						ARCHITECT/ENGINEERS:		Drawing Title ELECTRICAL DETAILS		Project Title RAYMOND G. MURPHY VA MEDICAL CENTER - REPLACE AUTOMATIC TRANSFER SWITCHES		Project Number 501-11-130		Office of Construction and Facilities Management			
		DIRECTOR		CHIEF OF SERVICES				NTD ARCHITECTURE 2800 North 44th Street, Suite 500 Phoenix, Arizona 85008 602-955-8844 <small>San Diego • Los Angeles • Atlanta • Dallas • Seattle • Phoenix • Tucson</small> 2009-0200-00				Location VA ALBUQUERQUE, NM		Building Number 41, 42, 43, 45, 46		E-505 Dwg. of			
		ASSOCIATE DIRECTOR		CHIEF OF PROJECT SECTION						Approved Project Director		Date 12/07/11		Checked TJC				Drawing Number E-505	
		ASSISTANT DIRECTOR										Drawn TJC		Dwg. of					
Revisions:		Date		CHIEF OF ENGINEERING															