

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE
1

OF PAGES

2. AMENDMENT/MODIFICATION NUMBER
A000033. EFFECTIVE DATE
02-07-20174. REQUISITION/PURCHASE REQ. NUMBER
564-17-2-082-00655. PROJECT NUMBER (if applicable)
NONE6. ISSUED BY
CODE 00502
ALEXANDRIA VA HEALTH CARE SYSTEM
NETWORK CONTRACTING OFFICE 16
ALEXANDRIA VA HEALTH CARE SYSTEM
PO BOX 69004
ALEXANDRIA LA 71306-90047. ADMINISTERED BY (If other than Item 6)
CODE 00502
DEPARTMENT OF VETERANS AFFAIRS
NETWORK CONTRACTING OFFICE 16
ALEXANDRIA VA HEALTH CARE SYSTEM
2495 SHREVEPORT HIGHWAY
PINEVILLE LA 71360-40048. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)
To all Offerors/Bidders(X) 9A. AMENDMENT OF SOLICITATION NUMBER
VA256-17-Q-0242

X 9B. DATED (SEE ITEM 11)

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

THE PURPOSE OF AMENDMENT A00003 IS TO POST VENDOR Q&A. THE CHANGES ARE AS FOLLOW:

- A. SEE ATTACHMENT B FOR QUESTIONS AND ANSWERS.
-
- B. ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

FELICIA LOVELADY
CONTRACTING OFFICER

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

BY _____
(Signature of Contracting Officer)

Attachment B

Questions Request Form

VA256-17-Q-0242

#	Question	Answer
1.	The walk-in box dimensions are larger than the room dimensions.	Custom walk-in refrigerator that is to be placed in a room with dimensions of 12' wide x 25' long x 8'9" high. Walk-in Cooler Exterior Dimensions: 15'-5" Length x 10'-1 3/4" Width x 8'6" Height, cannot be greater than these dimensions.
2.	There is no information on the refrigeration system; Is it indoor or outdoor? How long is the pipe run?	Refrigeration system should be rated for outdoor locations. Pipe run is approximately forty feet.
3.	How close can we unload the materials for the cooling unit?	The outside condensing units can be unloaded within 10 feet of where they will be placed. There is a loading dock near the lab to unload the cabinet and inside parts.
4.	Are there any limitations for bringing the materials into the room? Sharp turns? Narrow Hallways? Elevators?	No sharp turns, no narrow hallways. There is a big overhead door at the loading dock, when you go through the door there is an elevator. Weight limit is 5000 lbs.
5.	. What are the limitations for opening the door of the cooling unit in the room?	No limitations. This is an open room and nothing will be in the way of the door.
6.	Will the VA provide power for the cooling	Power is available. Vendor will be responsible

	unit?	for making electrical connections.
7.	If the VA will not provide power for the unit, what are the power capabilities of the room?	N/A
8.	How far away is the closest electrical panel if required to access?	Panel is near the location of where the condensing unit will be.
9.	Does the room have a drop ceiling to run wires to the nearest electrical panel if needed?	Yes
10	Is there enough room and capacity available on the electrical panel to add another breaker?	Yes
11	How much product is being stored w/in a 24 hr. period?	Roughly 720 cu feet of product (maximum)
12	Is the incoming & outgoing temps. consistent? 37 degrees?	Yes; maintain a range of to be 2-8 deg Celcius
13	Is it single or three phase?	Single Phase