



FEEDER SCHEDULE						
FEEDER ORIGINATION LOCATION	LOAD SERVED	NUMBER OF PARALLEL SETS	NUMBER OF PHASE & NEUTRAL CONDUCTORS PER CONDUIT	PHASE & NEUTRAL CONDUCTOR SIZE	EQUIPMENT GROUND CONDUCTOR SIZE	MINIMUM CONDUIT SIZE
130H	T130L	1	3	NO. 6	NO. 8	1-1/4
CB-2B	CB1315	1	4	NO. 3	NO. 6	1-1/4
T130L	130L	1	4	NO. 1/0	NO. 6	2

F7 FEEDER ROUTING DIAGRAM
NOT TO SCALE

100% SUBMITTAL

[illegible]