

EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE OR OTHER FIXTURE OR ASSEMBLY TO BE REMOVED

EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE OR OTHER FIXTURE OR ASSEMBLY TO REMAIN

NEW WALL

SMOKE TIGHT WALL

1-HOUR FIRE RATED WALL

2-HOUR FIRE RATED WALL

1 HOUR FIRE SMOKE RATED WALL

PROJECT LIMITS OF WORK


NO PIPING OR DUCTWORK SHALL BE ROUTED THROUGH ELECTRICAL AND/OR DATA ROOMS.

## 100% SUBMITTAL


<i>REVISION NO.</i>	<i>REVISION DESCRIPTION</i>		
<b>Revisions</b>		<b>By</b>	<b>Date</b>



Department of Veterans Affairs  
Medical Center  
1826 Veterans Blvd.  
Dublin, Ga. 31021



Architect/Engineer Address



151 LOCUST STREET, SUITE #1  
AVONDALE ESTATES, GA 30002

P 704.814.1325  
F 704.321.0833

WWW.HSHPC.COM

COPYRIGHT © 2011 HARRELL, SALTTRICK & HOPPER, PC  
HSH PROJECT # 10004

Recommended Approvals:	
1. MEDICAL DIRECTOR	6. OPERATIONS SERVICE LINE MANAGER
2. ASSOCIATE DIRECTOR	7. INFECTION CONTROL SAFETY MANAGER
3. CHIEF OF STAFF	8. SAFETY MANAGER
4. ASSOC. DIRECTOR	9. GENERAL ENGINEER
5. SERVICE LINE MGRS.	10. COTR

Drawing Title	FIRE PROTECTION DEMOLITION FLOOR PLAN
---------------	---

**FULLY SPRINKLERED**

Project Title	RENOVATE 13A FOR ENDOSCOPY SUITE
---------------	-------------------------------------

Drawn	Building Number	AutoCAD File Name
Checked	Reviewed	Const. Contract No.

Date  
June 10, 2011

Project Number  
557-10-108

DRAWING No.

FPD-101

