

1. EXISTING DUCTWORK FROM EXISTING AIR HANDLER IN ATTIC SHALL BE REMOVED BACK TO RISERS; REMOVE RISER TO 4" BELOW FINISHED FLOOR. PROVIDE INSULATED DUCT WITH INSULATION MATCH EXISTING.
2. REMOVE EXISTING EXHAUST FROM MECH. ROOM AND CHILLED WATER PIPING, CONDENSATE DRAIN PIPING AND PIPE HANGERS.
3. REMOVE EXISTING EXHAUST FROM MECH. ROOM DUCTS FROM FAN COIL UNITS.
4. REMOVE ALL EXISTING EXHAUST DUCTS, GRILLES, HANGERS, ETC.
5. RE-BALANCE EXISTING EXHAUST FANS AFFECTED BY THE DEMOLITION WORK.
6. REMOVE EXISTING AIR HANDLER AND EXHAUST FAN FROM MECH. ROOM.
7. RE-BALANCE EXISTING AHU IN THE ATTIC. SEE ADDITIONAL NOTES ON SHEET M-103.
8. ALL EXISTING TEMPERATURE CONTROL DEVICES, TUBING PANELS WIRING, CONDUCITS, ETC. REMOVE DISPOSAL/DELIVERY OF DEVICES TO THE OWNER, PER THE OWNER'S DIRECTIONS. CAP ALL PNEUMATIC TUBING OUTSIDE OF THE RENOVATED SPACE. REMOVE ALL EXISTING WIRING BACK TO LOCATIONS OUTSIDE OF RENOVATED SPACE AND MAKE SAFE.
9. COORDINATE SEALING OF ALL OPENINGS WHERE TUBING, CONDUCITS, WIRING, DUCTS, ETC. ENTER PROJECT.

THE MECHANICAL CONTRACTOR SHALL TAKE THE LEAD IN PREPARATION OF COORDINATION DRAWINGS. SUCH DRAWINGS SHALL BE ARRANGED AND DESIGNED THROUGHOUT AND FROM COORDINATION WITH ALL OTHER MAJOR AND MINOR SUBCONTRACTORS AND THE GENERAL CONTRACTOR. PROVIDE PLAN VIEWS, SECTIONS AND ELEVATIONS AS REQUIRED TO FULLY COORDINATE ALL NEW WORK WITH ITSELF AND EXISTING CONDITIONS. DRAW TO SCALE (AT NOT LESS THAN 1/8" = 1'-0"). DRAWINGS SHALL SHOW, BUT NOT BE LIMITED TO, THE FOLLOWING: ALL MAJOR AND MINOR AIR DISTRIBUTION, MECHANICAL EQUIPMENT, MECHANICAL PIPING, FIRE PROTECTION PIPING, ALL PLUMBING PIPING, CABLE TRAYS (WITH ELEVATIONS NOTED); LIGHTING FIXTURES (WHEN CEILING MOUNTED); CEILING GRID AND CEILING HEIGHT; MAJOR BEAMS AND JOISTS (WITH ELEVATIONS MARKED); FIRE ALARM DEVICES AND SPEAKERS (WHERE CEILING MOUNTED); ELECTRICAL CONDUITS; EQUIPMENT PROVIDED BY OTHERS THAT PENETRATE INTO CEILING CAVITIES OR IMPIDE THE ACCESS TO CEILING CAVITIES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL SECTIONS SHALL BE CUT THROUGH AREAS SHOWING MATERIALS AND SYSTEMS OF ALL CONTRACTS. IF THERE ARE ANY OUTSTANDING ISSUES THAT CANNOT BE RESOLVED, CONSULT WITH THE ARCHITECT AND/OR ENGINEER (THROUGH THE VA COTR) FOR GUIDANCE AND MAKE CORRECTIONS IN ACCORDANCE WITH DIRECTIONS GIVEN. IT IS IMPORTANT TO NOTE THAT FABRICATION CANNOT BEGIN UNTIL COORDINATION DRAWINGS TO BE REVIEWED AND APPROVED. MATERIAL, EQUIPMENT, SYSTEMS, ETC. PROCUREMENT OR INSTALLATION COMPLETED PRIOR APPROVAL. IF TAKEN WITHOUT CONTRACTOR'S OWN RISK AND MAY HAVE TO MODIFIED, MOVED AND/OR RECONFIGURED AT THE CONTRACTORS COST.

EXISTING WALL, DOOR, WINDOW, MILL/WORK, FIXTURE
OR OTHER FIXTURE OR ASSEMBLY TO BE REMOVED

EXISTING WALL, DOOR, WINDOW, MILL/WORK, FIXTURE
OR OTHER FIXTURE OR ASSEMBLY TO REMAIN

NEW WALL

SMOKE TIGHT WALL

1-HOUR FIRE RATED WALL

2-HOUR FIRE RATED WALL

1 HOUR FIRE SMOKE RATED WALL

PROJECT LIMITS OF WORK


NO PIPING OR DUCTWORK SHALL BE ROUTED
THROUGH ELECTRICAL AND/OR DATA ROOMS.

100% SUBMITTAL

REVISION NO.	REVISION DESCRIPTION		
Revisions		By	Date



Department of Veterans Affairs
Medical Center
1826 Veterans Blvd.
Dublin, Ga. 31021



Architect/Engineer Address

**Harrell,
Saltrick
&
Hopper**

Des
151
AVO

Design & Management Solutions for the Built Environment

151 LOCUST STREET, SUITE #1
AVONDALE ESTATES, GA 30002

P 704.814.1325
F 704.321.0833

WWW.HSHPC.COM

COPYRIGHT © 2011 HARRELL SALTRICK & HOPPER, PC
HSH PROJECT # 10004

Recommended Approvals:	
1. MEDICAL DIRECTOR	6. OPERATIONS SERVICE LINE MANAGER
2. ASSOCIATE DIRECTOR	7. INFECTION CONTROL SAFETY MANAGER
3. CHIEF OF STAFF	8. SAFETY MANAGER
4. ASSOC. DIRECTOR	9. GENERAL ENGINEER
5. SERVICE LINE MGRS.	10. COTR

Drawing Title	MECHANICAL DEMOLITION FLOOR PLAN - DUCTWORK
	FULLY SPRINKLERED

PROJECT TITLE Project Title RENOVATE 13A FOR ENDOSCOPY SUITE		
Drawn AGT	Building Number 	AutoCAD File Name
Checked	Reviewed	Const. Contract N

Date	June 10, 2011
Project Number	557-10-108
DRAWING No.	MD-101

Veterans Affairs