

01. COORDINATE LOCATION OF MEDICAL GAS CONNECTIONS WITH BOOM PROVIDED.
02. COORDINATE MEDICAL GAS CONNECTION TO HEADWALL WITH ACTUAL HEADWALL EQUIPMENT PROVIDED.
03. CONNECT NEW 3/8" COMPRESSED AIR TO NEW WALL WASH UNIT. TYPICAL OF 3 EACH. PROVIDE FLEXIBLE BRAIDED EPDM HOSE MINIMUM 150 PSI. VERIFY EXACT SIZE REQUIRED WITH GAS WASHER.
04. NO PIPING SHALL BE ROUTED THRU OR IN ELECTRICAL ROOM AND I.T. CLOSETS.
05. AIR PRESSURE REGULATING VALVE. 100 PSI INLET PRESSURE, 80 PSI OUTLET PRESSURE.
06. 2ND. FLOOR OXYGEN ISOLATION VALVE.

THE MECHANICAL CONTRACTOR SHALL TAKE THE LEAD IN PREPARATION OF COORDINATION DRAWINGS. SUCH DRAWINGS SHALL BE ARRANGED AND DESIGNED THROUGH AND FROM COORDINATION WITH ALL OTHER MAJOR AND MINOR SUBCONTRACTORS AND THE GENERAL CONTRACTOR. PROVIDE PLAN VIEW, SECTIONS AND ELEVATIONS AS REQUIRED TO FULLY COORDINATE ALL NEW WORK WITH EXISTING AND EXISTING CONDITIONS. DRAW TO SCALE (AT NOT LESS THAN 1/8" = 1'-0"). DRAWINGS SHALL SHOW, BUT NOT BE LIMITED TO, THE FOLLOWING: ALL AIR RAVINGS, ALL DUCTS, AIR DISTRIBUTION, MECHANICAL EQUIPMENT, MECHANICAL PIPING, FIRE PROTECTION PIPING, ALL PLUMBING PIPING, CABLE TRAYS (WITH ELEVATIONS NOTED); LIGHTING FIXTURES (INCLUDING MOUNTING); CEILING GRID AND CEILING HEIGHT; MAJOR BEAMS AND JOISTS (WITH ELEVATIONS MARKED); FIRE ALARM DEVICES AND SPEAKERS (WHERE MOUNTING); ELECTRICAL CONDUITS (WHERE LARGER THAN 2-INCH DIAMETER); ELECTRICAL BUSWAY AND REQUIRED CLEARANCES; EQUIPMENT TO BE PROVIDED BY OTHERS; EQUIPMENT, MATERIALS, AND SUPPLIES TO BE PROVIDED BY THE CONTRACTOR; AND ALL CEILING, FLOOR, DUCTWORK, OF OTHER EQUIPMENT. SECTIONS SHALL BE CUT THROUGH AREAS SHOWING MATERIALS AND SYSTEMS OF ALL CONTRACTS. IF THERE ARE ANY OUTSTANDING ISSUES THAT CANNOT BE RESOLVED, CONSULT WITH THE ARCHITECT AND/OR ENGINEER (THROUGH THE VA COTR) FOR GUIDANCE AND MAKE CORRECTIONS IN ACCORDANCE WITH DIRECTIONS GIVEN. IT IS IMPORTANT TO NOTE THAT FABRICATION CANNOT BEGIN UNTIL COORDINATION DRAWINGS HAVE BEEN REVIEWED BY THE MATERIALS, EQUIPMENT, AND SUPPLIES DIVISION. FOR INSTALLATION COMPLETED PRIOR TO APPROVAL, THE WORK AT THE CONTRACTORS OWN RISK AND MAY BE TO BE MODIFIED, MOVED, AND/OR RECONFIGURED AT THE CONTRACTORS COST.

EXISTING WALL, DOOR, WINDOW, MILLWORK, FUTURE
OR OTHER FIXTURE OR ASSEMBLY TO BE REMOVED.

EXISTING WALL, DOOR, WINDOW, MILLWORK, FUTURE
OR OTHER FIXTURE OR ASSEMBLY TO REMAIN.

NEW WALL

SMOKE TIGHT WALL

1-HOUR FIRE RATED WALL

2-HOUR FIRE RATED WALL


1 HOUR FIRE SMOKE RATED WALL

PROJECT LIMITS OF WORK

NO PIPING OR DUCTWORK SHALL BE ROUTED
THROUGH ELECTRICAL AND/OR DATA ROOMS.

A detailed floor plan of the first floor of Bldg. #13. The plan shows a central corridor system connecting various rooms. On the left side, there is a parking area and a room labeled 'Bldg. #13'. On the right side, there is a large ball field area. The plan includes a compass rose in the top right corner. A legend at the bottom right indicates that 'A' represents the first floor and 'B' represents the second floor. The plan shows a blacked-out area marked with a black rectangle and the number '13'.

100% SUBMITTAL

Date June 10, 2011	 Veterans Affairs
Project Number 557-10-108	
DRAWING No. P-103	

