

PLUMBING ATTIC PLAN—  
MEDICAL GAS



01. COORDINATE MEDICAL GAS PIPING, DOMESTIC WATER PIPING AND COMPRESSED AIR PIPING WITH CHASE LOCATION ON 2ND. FLOOR
02. PROVIDE NEW ISOLATION VALVE IN MEDICAL AIR SERVING 2ND FLOOR OF BUILDING 13. VALVE SHALL BE LOCKABLE TYPE. PROVIDE IDENTIFICATION TAG THAT READS MEDICAL AIR ISOLATION VALVE 13B.
03. PROVIDE NEW ISOLATION VALVE IN EXISTING MEDICAL VACUUM LINE SERVING 2ND. FLOOR OF BUILDING 13. VALVE SHALL BE LOCKABLE TYPE. PROVIDE IDENTIFICATION TAG THAT READS MEDICAL VACUUM ISOLATION VALVE 13B.

THE MECHANICAL CONTRACTOR SHALL TAKE THE LEAD IN PREPARATION OF COORDINATION DRAWINGS. SUCH DRAWINGS SHALL BE ARRANGED AND DESIGNED THROUGHOUT AND FROM COORDINATION WITH ALL OTHER MAJOR AND MINOR SUBCONTRACTORS AND THE GENERAL CONTRACTOR. PROVIDE PLAN VIEWS, SECTIONS AND ELEVATIONS AS REQUIRED TO FULLY COORDINATE ALL NEW WORK WITH EXISTING AND EXISTING CONDITIONS. DRAW TO SCALE (AT NOT LESS THAN 3/8" = 1'-0"). DRAWINGS SHALL SHOW, BUT NOT BE LIMITED TO: AIR HANDLING UNITS; DUCTWORK; AIR DISTRIBUTION; MECHANICAL EQUIPMENT; PIPING; PIPING SUPPORTS; PLUMBING FIXTURES; PLUMBING PIPING; CABLE TRAYS (WITH ELEVATIONS NOTED); LIGHTING FIXTURES (WHEN CEILING MOUNTED); CEILING GRID AND CEILING HEIGHT; MAJOR BEAMS AND JOISTS (WITH ELEVATIONS MARKED); FIRE ALARM DEVICES AND SPEAKERS (WHEN CEILING MOUNTED); ELECTRICAL CONDUITS LARGER THAN 2-INCH DIAMETER; ELECTRICAL SHEDS AND REQUIRED CLEARANCES; EQUIPMENT PROVIDED BY OTHERS THAT PROTRUDE INTO CEILING CAVITIES OR IMPIDE THE INSTALLATION OF CEILING DEVICES; EQUIPMENT PROVIDED BY OTHERS THAT ARE LOCATED IN OR ABOVE CEILING CAVITIES. PROVIDE ALL SECTIONS SHALL BE CUT THROUGH AREAS SHOWING MATERIALS AND SYSTEMS TO BE CONTRACTED. IF THERE ARE ANY OUTSTANDING ISSUES THAT CANNOT BE RESOLVED, CONSULT WITH THE ARCHITECT AND/OR ENGINEER (THROUGH THE VA COTR) FOR GUIDANCE AND MAKE CORRECTIONS IN ACCORDANCE WITH DIRECTIONS GIVEN. IT IS IMPORTANT TO NOTE THAT FABRICATION CANNOT BEGIN UNTIL COORDINATION DRAWINGS ARE THEN APPROVED BY THE ARCHITECT AND/OR ENGINEER. APPROVED COORDINATION DRAWINGS WILL BE USED TO APPROVE THE INSTALLATION. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROTECTION OF HIS OWN RISK AND MAY HAVE TO BE MOVED, MODIFIED AND/OR RECONFIGURED AT THE CONTRACTORS COST.

EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE  
OR OTHER FIXTURE OR ASSEMBLY TO BE REMOVED.

EXISTING WALL, DOOR, WINDOW, MILLWORK, FIXTURE  
OR OTHER FIXTURE OR ASSEMBLY TO REMAIN.

NEW WALL.

SMOKE TIGHT WALL.

1-HOUR FIRE RATED WALL.

2-HOUR FIRE RATED WALL.

1 HOUR FIRE SMOKE RATED WALL.

PROJECT LIMITS OR WORK

NO PIPING OR DUCTWORK SHALL BE ROUTED  
THROUGH ELECTRICAL AND/OR DATA ROOMS.

BLDG. #13


A = FIRST FLOOR  
B = SECOND FLOOR

100% SUBMITTAL

REVISION NO.	REVISION DESCRIPTION		
Revisions		By	Date




Department of Veterans Affairs  
Medical Center  
1826 Veterans Blvd.  
Dublin, Ga. 31021



SEAL

Architect/Engineer Address



**Design & Management Solutions for the Built Environment**  
151 LOCUST STREET, SUITE #1 P 704.814.1325  
AVONDALE ESTATES, GA 30002 F 704.321.0833  
WWW.HSHSPC.COM  
COPYRIGHT © 2011 HARRELL SALTRECK & HOPPER, PC  
HSH PROJECT # 10004

Recommended Approvals:	
1. MEDICAL DIRECTOR	6. OPERATIONS SERVICE LINE MANAGER
2. ASSOCIATE DIRECTOR	7. INFECTION CONTROL SAFETY MANAGER
3. CHIEF OF STAFF	8. SAFETY MANAGER
4. ASSOC. DIRECTOR	9. GENERAL ENGINEER
5. SERVICE LINE MGRS.	10. COTR

<div style="border: 1px solid black; width: 20px; height: 20px; margin: 0 auto;"></div>	Drawing Title
	<b>PLUMBING ATTIC PLAN AND RISER DIAGRAM</b>

**FULLY SPRINKLERED**

Project Title	<b>RENOVATE 13A FOR ENDOSCOPY SUITE</b>
---------------	---

Drawn	Building Number	AutoCAD File Name
Checked	Reviewed	Const. Contract No.

Date \_\_\_\_\_

Project Number

DRAWING No. \_\_\_\_\_

P-104

