SITE PLAN OF PROPOSED LOCATION FOR MOBILE SPD

GENERAL NOTES:

1. DO NOT USE WOOD TO SUPPORT UTILITIES; ANCHOR TO BUILDING STRUCTURE, NOT FASCIA/BRICK
2. MUST USE RIGID CONDUIT OUTSIDE OF BUILDING FOR ALL UTILITY RUNS
3. TIE-IN SPRINKLER FLOW STATION AND MSPD SMOKE DETECTORS INTO VA NOTIFIER FIRE ALARM SYSTEM AND INCLUDE PROGRAMMING.
4. ELECTRICAL FEEDS MUST BE ROUTED ABOVE LOADING DOCK IN ORDER TO ALLOW CLEARANCE OF SEMI-TRUCKS TO LOAD/UNLOAD
5. PROVIDE BREAKER(S) AT MAIN SWITCHBOARD, MDB, IN BASEMENT
6. ONCE MOBILE SPD IS REMOVED FROM SITE, LEAVE BREAKER IN SWITCHBOARD MDB THAT WAS INSTALLED TO SUPPORT MSPD
7. PROVIDE A LOCKABLE, WEATHER-PROOF CONNECTIONBOX FOR UTILITY DISCONNECTS OUTSIDE OF THE BUILDING
8. FIELD VERIFY EXACT CONNECTION LOCATIONS, UTILITY SUPPORT LOCATIONS, ROUTING, OFFSET HEIGHTS, AND ELEVATIONS.
9. WALKWAY SHALL CONNECT THE VENDOR'S DOORWAY TO THE ENTRANCES OF THE MEDICAL CENTER AND BE INDEPENDENTLY SUPPORTED
10. DO NOT RUN UTILITIES ALONG ROOF
11. ALL WATER AND SEWER CONNECTIONS ARE IN ACRE SUB-BASEMENT
12. SUB-BASEMENT IS APPROX. 6 FT, OTHER FLOORS ARE APPROX. 14 FT CLR HGT, REINFORCED CONCRETE SLAB FLOORS ARE APPROX. 12" THICK
13. COORDINATE INSTALLATIONS, ACCESS, AND SHUTDOWNS WITH THE MEDICAL CENTER COR AT LEAST 1 WEEK IN ADVANCE, INCLUDING TIE-IN OF UTILITIES PERFORMED ON NIGHTS AND WEEKENDS.