



BUILDING #74 - ACOUSTICAL TILE CEILING AFFECTED			
ROOM NO.	EXISTING CEILING HT. AFF	NEW CEILING HT. AFF	REMARKS
119	8'-0"	10'-4"	
120	8'-0"	10'-4"	
121	8'-0"	10'-4"	
124	8'-0"	10'-4"	
125	8'-0"	8'-0"	REMOVE & REPLACE @ SAME HEIGHT
125B	8'-0"	8'-0"	REMOVE & REPLACE @ SAME HEIGHT
125C	8'-0"	10'-4"	
126	8'-0"	10'-4"	
128	8'-1"	8'-0"	
130A	8'-0"	10'-4"	
130B	8'-0"	10'-4"	
130C	8'-0"	10'-4"	
130D	8'-1"	10'-4"	
130E	8'-0"	10'-4"	
130F	8'-0"	10'-4"	
131	8'-0"	10'-4"	
132	8'-0"	10'-4"	
133	8'-10"	10'-4"	
134	8'-10"	10'-4"	
142	8'-1"	8'-0"	

- NOTES (DWGS 74-E1 & 74-E2)
- SEE SHEET ENTITLED "TYPICAL BUILDING SERVICE SUBSTATION" FOR REQUIRED APPURTENANCES.
 - EQUIP INCOMING LINE LUGS TO RECEIVE 5 SETS OF 750 MCM CABLES.
 - INSTALL REMOVABLE BUS LINKS ACROSS SPACE FOR FUTURE MAIN BREAKER.
 - 2#12 CONT & 1#12 EGC - 3/4" C.
 - 4#12 CONT & 1#12 EGC - 3/4" C.
 - 6#12 CONT & 1#12 EGC - 3/4" C.
 - 8#12 CONT & 1#12 EGC - 1" C.
 - 10#12 CONT & 1#12 EGC - 1" C.
 - 12#12 CONT & 1#12 EGC - 1" C.
 - 14#12 CONT & 1#12 EGC - 1 1/4" C.
 - 3#10 & 1#10 EGC - 3/4" C.
 - 6#10 & 1#10 EGC - 1" C.
 - 9#10 & 1#10 EGC - 1" C.
 - 12#10 & 1#10 EGC - 1 1/4" C.
 - 15#10 & 1#10 EGC - 1 1/4" C.
 - 18#10 & 1#10 EGC - 1 1/4" C.
 - ONE RTD CABLE & 1#12 EGC - 3/4" C.
 - TWO RTD CABLES & 1#12 EGC - 3/4" C.
 - THREE RTD CABLES & 1#12 EGC - 1" C.
 - BRANCH CIRCUITS FROM MCC74A TO PUMPS AND COMPRESSORS
 - CONTROL WIRING FROM MCC74A TO PUMPS & COMPRESSORS
 - RTD CABLES FROM LRC74 TO PUMPS
 - FOR CONTINUATION SEE FIRST, SECOND AND ATTIC FLOOR PLANS
 - RUN INTO SERVICE ROOM. TERMINATE AND BUSH CONDUIT. RUN CONDUCTOR EXPOSED ON WALLS WITHIN SERVICE ROOM. CONNECT TO DOMESTIC HOT AND COLD WATER PIPES, MEDIUM PRESSURE STEAM SUPPLY PIPE, STEAM CONDENSATE RETURN PIPE, SECONDARY CHILLED WATER SUPPLY AND RETURN PIPES, AND SPRINKLER RISER PIPE AHEAD OF FIRST VALVE OR CONNECTION AFTER PENETRATING BUILDING WALL. DO NOT SPLICE CONDUCTOR.
 - CONNECT TO SPARE OVERCURRENT DEVICE
 - REMOVE ELEVEN 2 TUBE FLUORESCENT SURFACE MOUNTED FIXTURES FROM CORRIDORS AREA INCLUDED IN SPACES 135, 136, 137, 140, 141. REMOVE WIRING AND EXPOSED CONDUIT.
 - REMOVE ELEVEN 2 TUBE FLUORESCENT SURFACE MOUNTED FIXTURES FROM CORRIDOR AREA INCLUDED IN SPACES 201A, 240, 241, 242, 243, 244. REMOVE WIRING AND EXPOSED CONDUIT.
 - UP TO ATTIC VIA CLOSEST CHASE DESIGNATED AS "CHASE FOR CONDUITS RUNNING BETWEEN FLOORS".
 - UPDATE PANEL SCHEDULE.
 - EXISTING - EXTEND AS INDICATED USING #12 CONDUCTORS AND 3/4" C. UPDATE PANEL SCHEDULE.
 - CIRCUITS E3-10 & 19 WILL NOT BE REUSED - CIRCUITS SHALL BE SPARE.

32. RELOCATE EXISTING CONDUIT SERVING RECEPT & TW A/C UNITS CONFLICTING WITH NEW WORK. (REFERENCE F.C.O. #3)
33. RELOCATE CONDUIT IN COR. 138 & 142 TO FACILITATE INSTALLATION OF NEW WORK. (REFERENCE F.C.O. #4)

REVISION

NO.	DATE	DESCRIPTION
1	9-5-80	RECORD DRAWING REVISION.
2	8/13/78	REVISED LIGHTING IN S-W WING
REVISIONS		
SHEET TITLE		
BUILDING 74 FIRST FLOOR PLAN		
BLDG. NO.		
74		
PROJECT TITLE		
AIR CONDITION VARIOUS BUILDINGS		
DRAWN	CHECKED	DATE
HDB, KOH	WGM, DHJ	APRIL 27, 1978
ENGINEERS • ARCHITECTS • PLANNERS		DRAWING NUMBER
LYNCHBURG, VIRGINIA		74-E2R
APPROVAL PROJECT DIRECTOR		DWG. ISSUED OF 105
VETERANS ADMINISTRATION		658-036
LOCATION		
VAH, SALEM, VIRGINIA		

