


NOTE:

1. ALL DRIP POINTS ON STEAM MAINS SHALL BE PROVIDED WITH A 12" MINIMUM HIGH DRIP LEG FROM BOTTOM OF STEAM MAIN TO TRAP INLET. DRIP LEG SHALL HAVE 6" SCALE POCKET BELOW TRAP INLET.
2. PROVIDE BYPASS PIPING.

INVERTED BUCKET STEAM TRAP ASSEMBLY



NTS



Department of
Veterans Affairs

DETAIL TITLE / INVERTED BUCKET STEAM TRAP ASSEMBLY

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.:

SD232213-02.DWG