


NOTE:

1. ALL DRIP POINTS ON STEAM MAINS SHALL BE PROVIDED WITH A 12" MINIMUM HIGH DRIP LEG FROM BOTTOM OF STEAM MAIN TO TRAP INLET. DRIP LEG SHALL HAVE 6" SCALE POCKET BELOW TRAP INLET.

FLOAT AND THERMOSTATIC STEAM TRAP ASSEMBLY



NTS



Department of
Veterans Affairs

DETAIL TITLE / FLOAT AND THERMOSTATIC STEAM TRAP
ASSEMBLY

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD232213-03.DWG