

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400289	Description / Location:	Off-White/Tan Floor Tile		
Client No.:	FTW-001A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400290	Description / Location:	Black Mastic		
Client No.:	FTW-001B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 1.4	Chrysotile	None Detected	None Detected	PC 98.6	

Lab No.:	4400291	Description / Location:	Off-White/Tan Floor Tile		
Client No.:	FTW-002A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400292	Description / Location:	Sample Not Analyzed		
Client No.:	FTW-002B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
	Sample Not Analyzed		Sample Not Analyzed		

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Approved By: _____

Date: 8/18/2011

Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400293	Description / Location:	Off-White/Tan/Grey Floor Tile	
Client No.:	FTW-003A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400294	Description / Location:	Black Mastic	
Client No.:	FTW-003B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	2	Synthetic	98

Lab No.:	4400295	Description / Location:	Off-White/Tan/Grey Floor Tile	
Client No.:	FTW-004A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400296	Description / Location:	Black Mastic	
Client No.:	FTW-004B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	2	Synthetic	98

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400297	Description / Location:	Lt.Tan Floor Tile		
Client No.:	FTW-005A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400298	Description / Location:	Black Mastic		
Client No.:	FTW-005B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2	

Lab No.:	4400299	Description / Location:	Lt.Tan Floor Tile		
Client No.:	FTW-006A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400300	Description / Location:	Sample Not Analyzed		
Client No.:	FTW-006B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
	Sample Not Analyzed		Sample Not Analyzed		

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400301	Description / Location:	Black Floor Tile	
Client No.:	FTW-007A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 2.4	Chrysotile	None Detected	None Detected	PC 97.6

Lab No.:	4400302	Description / Location:	Black Mastic	
Client No.:	FTW-007B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400303	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-008A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400304	Description / Location:	Black Mastic	
Client No.:	FTW-008B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400305	Description / Location:	Tan Floor Tile		
Client No.:	FTW-009A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400306	Description / Location:	Yellow/Black Mastic		
Client No.:	FTW-009B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400307	Description / Location:	Tan Floor Tile		
Client No.:	FTW-010A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400308	Description / Location:	Black Mastic		
Client No.:	FTW-010B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400309	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-011A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400310	Description / Location:	Black Mastic	
Client No.:	FTW-011B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.6	Chrysotile	None Detected	None Detected	PC 98.4

Lab No.:	4400311	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-012A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400312	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-012B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400313	Description / Location:	Tan Floor Tile	
Client No.:	FTW-013A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400314	Description / Location:	Black Mastic	
Client No.:	FTW-013B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.4	Chrysotile	None Detected	None Detected	PC 98.6

Lab No.:	4400315	Description / Location:	Tan Floor Tile	
Client No.:	FTW-014A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400316	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-014B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400317	Description / Location:	Off-White/Tan Floor Tile	
Client No.:	FTW-015A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400318	Description / Location:	Yellow/Black Mastic	
Client No.:	FTW-015B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Lab No.:	4400319	Description / Location:	Off-White/Tan Floor Tile	
Client No.:	FTW-016A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400320	Description / Location:	Yellow/Black Mastic	
Client No.:	FTW-016B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400321	Description / Location:	Grey Floor Tile	
Client No.:	FTW-017A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400322	Description / Location:	Tan Mastic	
Client No.:	FTW-017B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400323	Description / Location:	Grey Floor Tile	
Client No.:	FTW-018A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400324	Description / Location:	Tan Mastic	
Client No.:	FTW-018B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400325	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-019A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400326	Description / Location:	Black Mastic	
Client No.:	FTW-019B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.5	Chrysotile	None Detected	None Detected	PC 98.5

Lab No.:	4400327	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-020A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400328	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-020B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400329	Description / Location:	Blue Floor Tile	
Client No.:	FTW-021A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 0.3	Chrysotile	None Detected	None Detected	PC 99.7

Lab No.:	4400330	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-021B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400331	Description / Location:	Blue Floor Tile	
Client No.:	FTW-022A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC Trace	Chrysotile	None Detected	None Detected	100

Lab No.:	4400332	Description / Location:	Black Mastic	
Client No.:	FTW-022B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.3	Chrysotile	2	Synthetic	PC 96.7

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400333	Description / Location:	Olive Floor Tile
Client No.:	FTW-023A		
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.:	4400334	Description / Location:	Black Mastic
Client No.:	FTW-023B		
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
PC 2.3	Chrysotile	None Detected	None Detected
			PC 97.7

Lab No.:	4400335	Description / Location:	Olive Floor Tile
Client No.:	FTW-024A		
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
None Detected	None Detected	None Detected	None Detected
			100

Lab No.:	4400336	Description / Location:	Sample Not Analyzed
Client No.:	FTW-024B		
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>
	Sample Not Analyzed		Sample Not Analyzed

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400337	Description / Location:	Off-White/Grey Floor Tile	
Client No.:	FTW-025A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400338	Description / Location:	Yellow Mastic	
Client No.:	FTW-025B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400339	Description / Location:	Off-White/Grey Floor Tile	
Client No.:	FTW-026A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400340	Description / Location:	Yellow Mastic	
Client No.:	FTW-026B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400341	Description / Location:	Off-White/Tan Floor Tile	
Client No.:	FTW-027A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400342	Description / Location:	Tan/Black Mastic	
Client No.:	FTW-027B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400343	Description / Location:	Off-White/Tan Floor Tile	
Client No.:	FTW-028A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400344	Description / Location:	Tan/Black Mastic	
Client No.:	FTW-028B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations:	NIST-NVLAP No. 101165-0	NY-DOH No. 11021	AIHA-LAP, LLC No. 100188
<i>This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government</i>			
<i>This report shall not be reproduced except in full, without written approval of the laboratory.</i>			

Analytical Method	EPA 600/R-93/116
--------------------------	------------------

Comments:	(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.
------------------	--

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400345	Description / Location:	Grey Cementitious	
Client No.:	FTW-029A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Lab No.:	4400346	Description / Location:	Tan Mastic	
Client No.:	FTW-029B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400347	Description / Location:	Grey Cementitious	
Client No.:	FTW-030A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Lab No.:	4400348	Description / Location:	Tan Mastic	
Client No.:	FTW-030B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400349	Description / Location:	Lt.Grey/Black Floor Tile	
Client No.:	FTW-031A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	1	Synthetic	99

Lab No.:	4400350	Description / Location:	Tan Mastic	
Client No.:	FTW-031B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400351	Description / Location:	Lt.Grey/Black Floor Tile	
Client No.:	FTW-032A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	1	Synthetic	99

Lab No.:	4400352	Description / Location:	Tan Mastic	
Client No.:	FTW-032B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400353	Description / Location:	Off-White/Tan Floor Tile		
Client No.:	FTW-033A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400354	Description / Location:	Sample Not Analyzed		
Client No.:	FTW-033B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
	Sample Not Analyzed		Sample Not Analyzed		

Lab No.:	4400355	Description / Location:	Off-White/Tan Floor Tile		
Client No.:	FTW-034A				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
None Detected	None Detected	None Detected	None Detected	100	

Lab No.:	4400356	Description / Location:	Black Mastic		
Client No.:	FTW-034B				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2	

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400357	Description / Location:	Lt.Tan/Brown Floor Tile	
Client No.:	FTW-035A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400358	Description / Location:	Black Mastic	
Client No.:	FTW-035B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	2	Synthetic	98

Lab No.:	4400359	Description / Location:	Off-White/Tan Floor Tile	
Client No.:	FTW-036A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400360	Description / Location:	Black Mastic	
Client No.:	FTW-036B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	2	Synthetic	98

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400361	Description / Location:	Off-White/Lt.Grey Floor Tile	
Client No.:	FTW-037A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400362	Description / Location:	Black Mastic	
Client No.:	FTW-037B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Lab No.:	4400363	Description / Location:	Off-White/Lt.Grey Floor Tile	
Client No.:	FTW-038A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400364	Description / Location:	Black Mastic	
Client No.:	FTW-038B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	Trace	Cellulose	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400365	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-039A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400366	Description / Location:	Yellow/Black Mastic	
Client No.:	FTW-039B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400367	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-040A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400368	Description / Location:	Yellow/Black Mastic	
Client No.:	FTW-040B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400369	Description / Location:	Off-White/Lt.Tan Floor Tile	
Client No.:	FTW-041A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400370	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-041B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400371	Description / Location:	Off-White/Lt.Tan Floor Tile	
Client No.:	FTW-042A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400372	Description / Location:	Black Mastic	
Client No.:	FTW-042B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.4	Chrysotile	None Detected	None Detected	PC 98.6

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.: 4400373 Description / Location: White/Yellow/Brown Floor Tile

Client No.: FTW-043A

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.: 4400374 Description / Location: Black Mastic

Client No.: FTW-043B

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2

Lab No.: 4400375 Description / Location: White/Yellow/Brown Floor Tile

Client No.: FTW-044A

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.: 4400376 Description / Location: Sample Not Analyzed

Client No.: FTW-044B

<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400377	Description / Location:	White/Tan Floor Tile	
Client No.:	FTW-045A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2

Lab No.:	4400378	Description / Location:	Black Mastic	
Client No.:	FTW-045B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.5	Chrysotile	None Detected	None Detected	PC 98.5

Lab No.:	4400379	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-046A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400380	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-046B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400381	Description / Location:	Off-White Floor Tile	
Client No.:	FTW-047A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 0.5	Chrysotile	None Detected	None Detected	PC 99.5

Lab No.:	4400382	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-047B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400383	Description / Location:	Off-White Floor Tile	
Client No.:	FTW-048A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 0.3	Chrysotile	None Detected	None Detected	PC 99.7

Lab No.:	4400384	Description / Location:	Black Mastic	
Client No.:	FTW-048B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.3	Chrysotile	None Detected	None Detected	PC 98.7

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400385	Description / Location:	Red Floor Tile		
Client No.:	FTW-049				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC Trace	Chrysotile	None Detected	None Detected	100	

Lab No.:	4400386	Description / Location:	Red Floor Tile		
Client No.:	FTW-050				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC Trace	Chrysotile	None Detected	None Detected	100	

Lab No.:	4400387	Description / Location:	Red Floor Tile		
Client No.:	FTW-051				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 0.3	Chrysotile	None Detected	None Detected	PC 99.7	

Lab No.:	4400387	Description / Location:	Black Mastic	Layer No.:	2
Client No.:	FTW-051				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2	

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400388	Description / Location:	Red Floor Tile	
Client No.:	FTW-052			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC Trace	Chrysotile	None Detected	None Detected	100

Lab No.:	4400389	Description / Location:	Off-White/Brown Floor Tile	
Client No.:	FTW-053			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.6	Chrysotile	None Detected	None Detected	PC 98.4

Lab No.:	4400389	Description / Location:	Yellow/Black Mastic	Layer No.: 2
Client No.:	FTW-053			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.3	Chrysotile	None Detected	None Detected	PC 98.7

Lab No.:	4400390	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-054			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400391	Description / Location:	White/Lt.Grey Floor Tile	
Client No.:	FTW-055			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400391	Description / Location:	Yellow/Black Mastic		Layer No.:	2
Client No.:	FTW-055					
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>		
PC Trace	Chrysotile	None Detected	None Detected		100	

Lab No.:	4400392	Description / Location:	White/Lt.Grey Floor Tile	
Client No.:	FTW-056			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400392	Description / Location:	Yellow/Black Mastic		Layer No.:	2
Client No.:	FTW-056					
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>		
PC 0.3	Chrysotile	None Detected	None Detected		PC 99.7	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400393	Description / Location:	Tan Floor Tile	
Client No.:	FTW-057			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400393	Description / Location:	Yellow/Black Mastic	Layer No.:	2
Client No.:	FTW-057				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC Trace	Chrysotile	None Detected	None Detected	100	

Lab No.:	4400394	Description / Location:	Tan Floor Tile	
Client No.:	FTW-058			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400394	Description / Location:	Yellow/Black Mastic	Layer No.:	2
Client No.:	FTW-058				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC Trace	Chrysotile	None Detected	None Detected	100	

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400395	Description / Location:	Cream/Brown Floor Tile	
Client No.:	FTW-059			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.6	Chrysotile	None Detected	None Detected	PC 98.4

Lab No.:	4400395	Description / Location:	Black Mastic	Layer No.:	2
Client No.:	FTW-059				
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>	
PC 1.4	Chrysotile	None Detected	None Detected	PC 98.6	

Lab No.:	4400396	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-060			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
Sample Not Analyzed		Sample Not Analyzed		

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400397	Description / Location:	White/Grey Floor Tile	
Client No.:	FTW-061			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 2.4	Chrysotile	None Detected	None Detected	PC 97.6

Lab No.:	4400397	Description / Location:	Black Mastic	Layer No.: 2
Client No.:	FTW-061			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 1.8	Chrysotile	None Detected	None Detected	PC 98.2

Lab No.:	4400398	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-062			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
Sample Not Analyzed		Sample Not Analyzed		

Lab No.:	4400399	Description / Location:	Tan Rubber	
Client No.:	FTW-063			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400400	Description / Location:	Tan Rubber	
Client No.:	FTW-064			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400401	Description / Location:	Dk.Brown Rubber	
Client No.:	FTW-065A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400402	Description / Location:	Dk.Brown Mastic	
Client No.:	FTW-065B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400403	Description / Location:	Off-White Ceiling Tile	
Client No.:	FTW-066			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	90	Mineral Wool	10

Accreditations:	NIST-NVLAP No. 101165-0	NY-DOH No. 11021	AIHA-LAP, LLC No. 100188
<i>This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government</i>			
<i>This report shall not be reproduced except in full, without written approval of the laboratory.</i>			

Analytical Method	EPA 600/R-93/116
--------------------------	------------------

Comments:	(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.
------------------	--

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client: L.Robert Kimball & Assoc.Inc.

415 Moon Clinton Rd.

Moon Township PA 15108

Report Date: 8/18/2011

Report No.: 249524

Project: VAHospital;Bldg1;FtWayne,IN

Project No.: 11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400404	Description / Location:	Off-White Ceiling Tile	
Client No.:	FTW-067			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	90	Mineral Wool	10

Lab No.:	4400405	Description / Location:	Tan Insulation	
Client No.:	FTW-068			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	5	Cellulose	90
		5	Fibrous Glass	

Lab No.:	4400406	Description / Location:	Tan Insulation	
Client No.:	FTW-068-1			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	5	Cellulose	90
		5	Fibrous Glass	

Lab No.:	4400407	Description / Location:	Dk.Brown Caulk	
Client No.:	FTW-069			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Accreditations:

NIST-NVLAP No. 101165-0

NY-DOH No. 11021

AIHA-LAP, LLC No. 100188

*This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government**This report shall not be reproduced except in full, without written approval of the laboratory.*

Analytical Method

EPA 600/R-93/116

Comments:

(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400408	Description / Location:	Dk.Brown Caulk	
Client No.:	FTW-069-1			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400409	Description / Location:	Black Tar	
Client No.:	FTW-070			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 5.6	Chrysotile	None Detected	None Detected	PC 94.4

Lab No.:	4400410	Description / Location:	Off-White Ceiling Tile	
Client No.:	FTW-071			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Lab No.:	4400411	Description / Location:	Off-White Ceiling Tile	
Client No.:	FTW-071			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	80	Mineral Wool	20

Accreditations:	NIST-NVLAP No. 101165-0	NY-DOH No. 11021	AIHA-LAP, LLC No. 100188
<i>This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government</i>			
<i>This report shall not be reproduced except in full, without written approval of the laboratory.</i>			

Analytical Method	EPA 600/R-93/116
--------------------------	------------------

Comments:	(PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.
------------------	--

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400412	Description / Location:	Tan/White Sheetrock	
Client No.:	FTW-072			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	50	Cellulose	93
		2	Fibrous Glass	

Lab No.:	4400413	Description / Location:	Off-White Ceiling Tile	
Client No.:	FTW-073			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	80	Mineral Wool	20

Lab No.:	4400414	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-118A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400415	Description / Location:	Black Mastic	
Client No.:	FTW-118B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
PC 2.8	Chrysotile	None Detected	None Detected	PC 97.2

Accreditations: **NIST-NVLAP No. 101165-0** **NY-DOH No. 11021** **AIHA-LAP, LLC No. 100188**

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government

This report shall not be reproduced except in full, without written approval of the laboratory.

Analytical Method EPA 600/R-93/116

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011

CERTIFICATE OF ANALYSIS

Client:	L.Robert Kimball & Assoc.Inc.	Report Date:	8/18/2011
	415 Moon Clinton Rd.	Report No.:	249524
	Moon Township PA 15108	Project:	VAHospital;Bldg1;FtWayne,IN
		Project No.:	11-1300-0017-0011

BULK SAMPLE ANALYSIS SUMMARY

Lab No.:	4400416	Description / Location:	Lt.Tan Floor Tile	
Client No.:	FTW-119A			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
None Detected	None Detected	None Detected	None Detected	100

Lab No.:	4400417	Description / Location:	Sample Not Analyzed	
Client No.:	FTW-119B			
<u>% Asbestos</u>	<u>Type</u>	<u>% Non-Asbestos Fibrous Material</u>	<u>Type</u>	<u>% Non-Fibrous Material</u>
	Sample Not Analyzed		Sample Not Analyzed	

Accreditations:	NIST-NVLAP No. 101165-0	NY-DOH No. 11021	AIHA-LAP, LLC No. 100188
	<i>This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA or any agency of the U.S. government</i>		
	<i>This report shall not be reproduced except in full, without written approval of the laboratory.</i>		

Analytical Method	EPA 600/R-93/116
--------------------------	------------------

Comments: (PC) Indicates Stratified Point Count Method performed. Method not performed unless stated. Quantification at <0.25% by volume is possible with this method. (PC-Trace) represents this limit of quantitation. (PC-Trace) means that asbestos was detected but is not quantifiable under the Point Counting regimen. Analysis includes all distinct separable layers in accordance with EPA 600 Method. If not reported or otherwise noted, layer is either not present or the client has specifically requested that it not be analyzed. Small asbestos fibers may be missed by PLM due to resolution limitations of the optical microscope. Therefore, negative PLM results cannot be guaranteed. Electron Microscopy can be used as a confirming technique. Regulatory Limit is based upon the sample matrix.

Analysis Performed By: M. Mirza

Date: 8/18/2011