


one eighth inch = one foot
one quarter inch = one foot
one half inch = one foot
three eighths inch = one foot
three quarters inch = one foot
one inch = one foot
one and one half inches = one foot
two inches = one foot
three inches = one foot


C:\Users\ashcraft\Documents\1724-10_Elec_Central+14_ashcraft.dwg 10/17/2016 9:44:03 AM

REVISIONS		
Revision #	Description	Date
SUBMISSIONS		
BID DOCUMENTS		10-13-2016
100% CONSTRUCTION DOCUMENTS		3-25-2016
95% CONSTRUCTION DOCUMENTS		12-17-2015
65% CONSTRUCTION DOCUMENTS		8-14-2015
35% CONSTRUCTION DOCUMENTS		5-15-2015




VA NORTHERN INDIANA
HEALTH CARE SYSTEM,
FORT WAYNE
2121 Lake Ave., Fort
Wayne, IN 46805

ARCHITECT/ENGINEERS:



AMERICAN
STRUCTUREPOINT
INC.

7260 SHADELAND STATION
INDIANAPOLIS, IN 46256-3957
TEL 317 547 5560 FAX 317 543 0270
www.structurepoint.com



6250 Haverstick Road
Suite 285
Indianapolis, IN 46240
317 636 8363

CONSULTANTS:

USFin Development, LLC
1105 West Weir Street
Litchfield, Illinois 62056

WS DESIGN
1105 West Weir Street
Litchfield, Illinois 62056

RTM Consultants
6640 Parkdale Place, Suite J
Indianapolis, IN 46254



Drawing Title
EQUIPMENT DATA SCHEDULE

Approved: Project Director

Project Title
Renovate and Upgrade Patient
Areas, 4th Floor

Location
2121 Lake Ave., Fort Wayne, IN 46805

Date
2016.10.13

Checked
TJB

Drawn
ATE


Project Number
#610A4-08-104

Building Number
01

Drawing Number
MEP-001

Dwg. 83 of 138

Office of
Construction
and Facilities
Management

 Department of
Veterans Affairs

(1) SPECIFICATION DIVISION NUMBER: DIVISION 22 - PLUMBING DIVISION 23 - MECHANICAL DIVISION 26 - ELECTRICAL			(2) REFER TO FEEDER SCHEDULE WHEN THIS COLUMN CONTAINS A FEEDER DESIGNATION INSTEAD OF CONDUCTOR SIZE.			(3) DISCONNECT TYPE: NF - NONFUSED F - FUSED TOG - TOGGLE REC - DUPLEX RECEPTACLE			(4) STARTER TYPE: COMB1 - COMBINATION FULL VOLTAGE NON-REVERSING MAGNETIC STARTER WITH FUSED DISCONNECT SWITCH COMB2 - COMBINATION FULL VOLTAGE NON-REVERSING MAGNETIC STARTER WITH UNFUSED DISCONNECT SWITCH COMB3 - COMBINATION FULL VOLTAGE NON-REVERSING MAGNETIC STARTER WITH THERMAL MAGNETIC MOLDED CASE CIRCUIT BREAKER DISCONNECT. COMB4 - COMBINATION FULL VOLTAGE NON-REVERSING MAGNETIC STARTER WITH MAGNETIC ONLY MOLDED CASE CIRCUIT BREAKER DISCONNECT			(5) ACCESSORIES: FVNR - FULL VOLTAGE NON-REVERSING MAGNETIC STARTER WITHOUT DISCONNECT MAN - MANUAL STARTER SDS - STAR DELTA STARTER PWCP - PREWIRED CONTROL PANEL VFD - VARIABLE FREQUENCY DRIVE 2S2W - 2 SPEED 2 WINDING 2S1W - 2 SPEED SINGLE WINDING FSC - FAN SPEED CONTROLLER			(6) REMARKS: 1. FIRE ALARM INTERLOCK 2. INTEGRAL DISCONNECT SWITCH BY DIVISION 23. 3. MOUNT DISCONNECT SWITCH ON EQUIPMENT HOUSING. 4. INDOOR UNIT WIRED FROM EXTERIOR CU													
ALL MAGNETIC AND SOLID STATE STARTERS ARE TO BE EQUIPPED WITH AUXILIARY CONTACTS, PILOT LIGHTS AND FUSED CONTROL POWER TRANSFORMERS. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.																												
EQUIPMENT DATA SCHEDULE																												
MARK	Mark	EQUIPMENT	LOCATION	FURNISH. BY (1)	MOTOR OR EQUIPMENT DATA					FED FROM	BRANCH CIRCUIT (2)	DISCONNECT SWITCH AT EQUIPMENT					STARTER					REMARKS (6)						
					HP	KW	AMPS	VOLTS	PHASE			INST. BY	CONN. BY	TYP E (3)	NEMA ENCLOS. TYPE	SWITCH/ FUSE SIZE	FURN. BY	INST. BY	CONN. BY	NEMA SIZE	NEMA ENCLOS. TYPE		TYPE (4)	BREAKER/ TRIP	ACCES. (5)	FURNISH. BY	CONN. BY	CONTROL WIRING BY
ACU	1	AIR CONDITIONING UNIT	4110	23	-	-	1	200	1	23	26	CU-1	-	-	-	-/-	-	-	-	-	-	PWCP	-	-	23	26	23	4
ACU	2	AIR CONDITIONING UNIT	4111	23	-	-	1	200	1	23	26	CU-2	-	-	-	-/-	-	-	-	-	-	PWCP	-	-	23	26	23	4
AHU-RF	1	AIR HANDLER UNIT - RETURN FAN	ROOF	23	7.5	-	-	460	3	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	F	3R	30/20	26	26	26	-	-	VFD	-	-	23	26	23	1,3
AHU-RF	2	AIR HANDLER UNIT - RETURN FAN	ROOF	23	10	-	-	460	3	23	26	SEE PLANS	(3)#10, (1)#10 GRD, 1/2-INCH C	F	3R	30/25	26	26	26	-	-	VFD	-	-	23	26	23	1,3
AHU-SF	1	AIR HANDLER UNIT - SUPPLY FAN	ROOF	23	20	-	-	460	3	23	26	SEE PLANS	(3)#6, (1)#10 GRD, 3/4-INCH C	F	3R	60/60	26	26	26	-	-	VFD	-	-	23	26	23	1,3
AHU-SF	2	AIR HANDLER UNIT - SUPPLY FAN	ROOF	23	20	-	-	460	3	23	26	SEE PLANS	(3)#6, (1)#10 GRD, 3/4-INCH C	F	3R	60/60	26	26	26	-	-	VFD	-	-	23	26	23	1,3
CH	1	CHILLER	ROOF	23	-	-	206.3	460	3	23	26	SEE PLANS	(3)250 KCMIL, (1)#4 GRD, 2-INCH C	NF	3R	400/-	26	26	26	-	-	PWCP	-	-	23	26	23	-
CU	1	CONDENSING UNIT	EXTERIOR	23	-	-	25	200	1	23	26	SEE PLANS	(3)#10, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	26	26	26	-	-	PWCP	-	-	23	26	23	-
CU	2	CONDENSING UNIT	EXTERIOR	23	-	-	13	200	1	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	26	26	26	-	-	PWCP	-	-	23	26	23	-
EF	1	EXHAUST FAN	ROOF	23	1/2	-	-	460	3	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	23	23	26	0	3R	COMB2	-	HOAP	23	26	23	2
EF	2	EXHAUST FAN	ROOF	23	1/2	-	-	460	3	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	23	23	26	0	3R	COMB2	-	HOAP	23	26	23	2
ERU	1	ENERGY RECOVERY UNIT - SUPPLY FAN, RETURN FAN	ROOF	23	3,3	-	-	460	3	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	-	-	-/-	-	-	26	-	-	PWCP	-	-	23	26	23	2
ERU	2	ENERGY RECOVERY UNIT - SUPPLY FAN, RETURN FAN	ROOF	23	5,3	-	-	460	3	23	26	SEE PLANS	(3)#12, (1)#12 GRD, 1/2-INCH C	-	-	-/-	-	-	26	-	-	PWCP	-	-	23	26	23	2
UH	1	UNIT HEATER	ROOF	23	-	2	-	277	1	23	26	SEE PLANS	(2)#12, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	26	26	26	-	-	PWCP	-	-	23	26	23	-
UH	2	UNIT HEATER	ROOF	23	-	2	-	277	1	23	26	SEE PLANS	(2)#12, (1)#12 GRD, 1/2-INCH C	NF	3R	30/-	26	26	26	-	-	PWCP	-	-	23	26	23	-

100% CONSTRUCTION DOCUMENTS
FULLY SPRINKLERED