

Attachment B
Policy Memorandum 578-02-001-088(R-3)
November 25, 2014

EDWARD HINES JR. VA HOSPITAL
FACILITIES MANAGEMENT SERVICE

**INTERIM LIFE SAFETY MEASURES
CONSTRUCTION PROJECT EVALUATION WORKSHEET**

PROJECT TITLE/NUMBER: Abate Asbestos in Room C129, Bldg. 200, 578-16-041

BUILDING/ROOM NUMBER: Room C129

SERVICE/SECTION RESPONSIBLE: Project Planning

EFFECTS ON LIFE SAFETY

Provide a brief description of the project and any effects it is likely to have on life safety. Examples include: closing of an exit; use or storage of flammable materials on-site; installation of a dust barrier; blocking streets, driveways or access roads; impairment of fire detection and/or suppression systems; and removal of doors.

Abate asbestos containing materials in Room C129, Bldg. 200, Hines VA.

The only doors that will be blocked off are the doors that lead into the space.

The contractor will install containment barriers outside of the room in the corridor for purpose of dust mitigation and for the prevention of the escape of asbestos fibers. Contractor shall package and dispose of Asbestos Containing Materials (ACM) in accordance with applicable standards and regulations. Quality Control and Industrial Hygienist monitoring services will be provided.

SPECIFIC SAFETY CONCERNS

Will any of the work to be performed during this project as currently planned compromise or impair the use of the critical elements of fire protection listed below?

1. FIRE ALARM SYSTEMS: YES ____ NO XX

If YES is checked above, provide additional details, including number of devices affected and length of time systems will be impaired, on a separate sheet.

2. AUTOMATIC FIRE SPRINKLER SYSTEMS: YES ____ NO xxx

If YES is checked above, provide additional information including the size and occupancy of the area affected, and the anticipated duration of the impairment.

3. EXITS (STAIRWELLS, CORRIDORS & DOORS): YES xxx NO ____

If YES is checked above, provide additional information including the type, number, and location of exits, which will be obstructed, and the anticipated duration of the impairment.

Containment barriers will extend out into the corridor outside of the room for approximately 3 feet for the duration of the project.

4. ACCESS TO EMERGENCY VEHICLES & PERSONNEL: YES ____ NO xxx

If YES is checked above, provide additional information including location of blockage, how access will be obstructed, and the anticipated duration of the impairment.

5. INTEGRITY OF SMOKE &/OR FIRE COMPARTMENTS: YES ____ NO xxx

If YES is checked above, provide additional information including size, location, number, and purpose of penetrations, which will be made.

Ronald Hofer

Person responsible for construction projects
And/or activities, including work/projects

1-3-17

Date

1-6-17

Date

Service/Section Chief