





DRAWING NOTES:

- ① PRIOR TO DEMOLITION OF CHILLED WATER PIPING IN CHASES, CONTRACTOR SHALL REMOVE AND ABATE ASBESTOS CONTAINING MATERIAL ON CHILLED WATER, HOT WATER, STEAM, AND CONDENSATE RETURN PIPING. SEE SPECIFICATION SECTIONS 02 41 00 - DEMOLITION AND 02 82 11 - TRADITIONAL ASBESTOS ABATEMENT FOR ADDITIONAL INFORMATION.
- ② DEMO CHILLED WATER PIPING FROM PUMP ROOM TO ATTIC AHU'S.



CONSTRUCTION DOCUMENTS



 T V H S NASHVILLE CAMPUS		 T V H S MURFREESBORO CAMPUS	
<h1>Tennessee Valley Healthcare System</h1>			
TENNESSEE VALLEY HEALTHCARE SYSTEM MURFREESBORO CAMPUS		Drawing Title <h2>MECHANICAL RISER DEMOLITION</h2>	
Approved: —		Approved: Facility Manager	
Approved: —		Approved: Director	
Project Title <h3>REPLACE ATTIC AHUS BUILDING 6</h3>		Date 01/20/2012	
Building Number 6		Project No. 0204A-11-204	
Checked TCT		DRAWING NO. 6-M8	
Drawn SP		FILE NAME 0027002	
Location TVHS — YORK CAMPUS			
Veterans Administration			