

**SECTION 09 72 00  
WALL COVERINGS**

**PART 1 - GENERAL**

**1.1 RELATED DOCUMENTS**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.2 SUMMARY**

- A. Section Includes:

1. Vinyl wall covering. Custom digitized mural-like image printed on Type II commercial wall vinyl. Images and colors provided by Owner.

- B. Related Sections:

1. Division 09 Section "Interior Painting" for priming wall surfaces

**1.3 ACTION SUBMITTALS**

- A. Product Data: For each type of product indicated. Include data on physical characteristics, durability, fade resistance, and flame-resistance characteristics.

- B. LEED Submittals:

1. Product Data for Credit IEQ 4.1: For adhesives, documentation including printed statement of VOC content.
2. Laboratory Test Reports for Credit IEQ 4: For wall covering systems and adhesives, documentation indicating that products comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

- C. Shop Drawings: Show location and extent of each wall-covering type. Indicate pattern placement, seams and termination points.

- D. Samples for Verification: Full width by ~~36-inch~~ long section of wall covering.

1. Sample from same print run or dye lot to be used for the Work, with specified treatments applied. Show complete pattern repeat. Mark top and face of fabric.
2. Sample from same flitch to be used for the Work, with specified finish applied.

- E. Product Schedule: For wall coverings. Use same designations indicated on Drawings.

#### **1.4 INFORMATIONAL SUBMITTALS**

- A. Qualification Data: For qualified testing agency.
- B. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for wall covering.

#### **1.5 CLOSEOUT SUBMITTALS**

- A. Maintenance Data: For wall coverings to include in maintenance manuals.

#### **1.6 MAINTENANCE MATERIAL SUBMITTALS**

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Wall-Covering Materials: For each type, full-size units equal to 5 percent of amount installed.

#### **1.7 QUALITY ASSURANCE**

- A. Fire-Test-Response Characteristics: As determined by testing identical wall coverings applied with identical adhesives to substrates according to test method indicated below by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
  - 1. Surface-Burning Characteristics: As follows, per ASTM E 84:
    - a. Flame-Spread Index: 25 or less.
    - b. Smoke Development Index 450 or less

#### **1.8 PROJECT CONDITIONS**

- A. Environmental Limitations: Do not deliver or install wall coverings until spaces are enclosed and weathertight, wet work in spaces is complete and dry, work above ceilings is complete, and temporary HVAC system is operating and maintaining ambient temperature and humidity conditions at occupancy levels during the remainder of the construction period.
- B. Lighting: Do not install wall covering until a permanent level of lighting is provided on the surfaces to receive wall covering.

- C. Ventilation: Provide continuous ventilation during installation and for not less than the time recommended by wall-covering manufacturer for full drying or curing.

## **PART 2 - PRODUCTS**

### **2.1 PERFORMANCE REQUIREMENTS**

- A. Low-Emitting Materials: Wall covering system shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

### **2.2 WALL COVERINGS**

- A. General: Provide rolls of each type of wall covering from same print run or dye lot.

### **2.3 VINYL WALL COVERING (VWC)**

- A. Vinyl Wall-Covering Standards: Provide mildew-resistant products complying with the following:
1. FS CCC-W-408D and CFFA-W-101-D for Type II, Medium-Duty products.
  2. Products: Subject to compliance with requirements, provide one of the following
    - a. MDC Wallcoverings
    - b. Designtex
    - c. Koroseal Interior Products
- B. Total Weight: 20oz per lineard yd
- C. Width: As required per drawings
- D. Backing: Osnaburg or polyster nonwoven fabric.
1. Fiber Content: Cotton/Polyester
- E. Stain-Resistant Coating: Per manufacturer's standards
- F. Colors, Textures, and Patterns: Matte finish. Match Architect's graphics

**2.4 ACCESSORIES**

- A. Adhesive: Mildew-resistant, nonstaining, strippable adhesive, for use with specific wall covering and substrate application; as recommended in writing by wall-covering manufacturer.
  - 1. Adhesive shall have VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Adhesive shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- B. Primer/Sealer: Mildew resistant, complying with requirements in Division 09 Section "Interior Painting " and recommended in writing by wall-covering manufacturer for intended substrate.
- C. Wall Liner: Nonwoven, synthetic underlayment and adhesive as recommended by wall-covering manufacturer.
- D. Seam Tape: As recommended in writing by wall-covering manufacturer.
- E. Metal Primer: Interior ferrous metal primer complying with Division 09 Section "Interior Painting."

**PART 3 - EXECUTION****3.1 EXAMINATION**

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for levelness, wall plumbness, maximum moisture content, and other conditions affecting performance of the Work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.
- C. All building existing chalkboards to remain shall be covered V.I.F.

**3.2 PREPARATION**

- A. Comply with manufacturer's written instructions for surface preparation.
- B. Clean substrates of substances that could impair bond of wall covering, including dirt, oil, grease, mold, mildew, and incompatible primers.
- C. Prepare substrates to achieve a smooth, dry, clean, structurally sound surface free of flaking, unsound coatings, cracks, and defects.

1. Moisture Content: Maximum of 5 percent on new plaster, concrete, and concrete masonry units when tested with an electronic moisture meter.
  2. Plaster: Allow new plaster to cure. Neutralize areas of high alkalinity. Prime with primer as recommended in writing by primer/sealer manufacturer and wall-covering manufacturer.
  3. Metals: If not factory primed, clean and apply metal as recommended in writing by primer/sealer manufacturer and wall-covering manufacturer.
  4. Gypsum Board: Prime with primer as recommended in writing by primer/sealer manufacturer and wall-covering manufacturer.
  5. Painted Surfaces: Treat areas susceptible to pigment bleeding.
- D. Check painted surfaces for pigment bleeding. Sand gloss, semigloss, and eggshell finish with fine sandpaper.
- E. Remove hardware and hardware accessories, electrical plates and covers, light fixture trims, and similar items.
- F. Acclimatize wall-covering materials by removing them from packaging in the installation areas not less than 24 hours before installation.
- G. Install wall liner, with no gaps or overlaps, where required by wall-covering manufacturer. Form smooth wrinkle-free surface for finished installation. Do not begin wall-covering installation until wall liner has dried.

### 3.3 INSTALLATION

- A. General: Comply with wall-covering manufacturers' written installation instructions applicable to products and applications indicated except where more stringent requirements apply.
- B. Cut wall-covering strips in roll number sequence. Change roll numbers at partition breaks and corners.
- C. Install strips in same order as cut from roll.
- D. Install reversing every other strip.
- E. Install wall covering with no gaps or overlaps, no lifted or curling edges, and no visible shrinkage.
- F. Install seams vertical and plumb at least 6 inches from outside corners and 3 inches from inside corners unless a change of pattern or color exists at corner. No horizontal seams are permitted.
- G. Fully bond wall covering to substrate. Remove air bubbles, wrinkles, blisters, and other defects.
- H. Trim edges and seams for color uniformity, pattern match, and tight closure. Butt seams without any overlay or spacing between strips.

**3.4 CLEANING**

- A. Remove excess adhesive at finished seams, perimeter edges, and adjacent surfaces.
- B. Use cleaning methods recommended in writing by wall-covering manufacturer.
- C. Replace strips that cannot be cleaned.
- D. Reinstall hardware and hardware accessories, electrical plates and covers, light fixture trims, and similar items.

END OF SECTION