

PANELBOARD SCHEDULE										NOTES:
			SE RATED <input type="checkbox"/>		COMPUTER GRADE <input type="checkbox"/>	FEED-THRU LUGS <input type="checkbox"/>		SUB-FEED BREAKER <input type="checkbox"/>		
			HINGED TRIM <input type="checkbox"/>		200% NEUTRAL <input type="checkbox"/>	SUB-FEED LUGS <input type="checkbox"/>		ISOLATED GND BUS <input type="checkbox"/>		
NAME	LOCATION	SOURCE	RATING (AMPS)		PHASE/ WIRE	VOLTAGE	MOUNTING	KA/IC	MODEL	NEMA TYPE
3LL-B	CORR. B-WING	GENERATOR	100A/3P		3Ø / 4W	208Y/120	FLUSH		GTE SYLVANIA	1
CKT NO.	DESCRIPTION	BREAKER	KVA LOAD				BREAKER	DESCRIPTION		CKT NO.
1	EXISTING LOAD	20A/1P	LITG	RCPT	MOTOR	HIG	HIG	MOTOR	RCPT	LITG
3	EXISTING LOAD	20A/1P								2
5	EXISTING LOAD	20A/1P								4
7	FIRE ALARM NODE PNL	20A/1P								6
9	CORE-A WING 301 DOOR	20A/1P								8
11	B WING LITG	20A/1P								10
13	SPARE	20A/1P								12
15	C WING LITG	20A/1P								14
17	COMPUTER RECPT 308B	20A/1P								16
19	EXISTING LOAD	20A/1P								18
21	SPD LIGHTS	20A/1P								20
23	PYXIS RM 308B 14	20A/1P								22
25	3A IDF CLOSET RCPT	20A/1P								24
27	EXHAUST FAN EP2-SPD	20A/1P								26
29	FIRE ALARM CTRL PNL	20A/1P								28
31										30
33										32
35	MAIN	100A/3P								34
LEFT SIDE SUB-TOTAL			0.0	0	0	0	0	0	0	0
RIGHT SIDE SUB-TOTAL			0	0	0	0	0	0	0	0
CONNECTED SUB-TOTAL			0	0	0	0	0	0	0	0
DEMAND FACTOR			1	10+5	0.8	0.8				
SUB-TOTAL			0	0	0	0				
TOTAL KVA:			0							
TOTAL AMPS:			0.0							

PANELBOARD SCHEDULE										NOTES:
			SE RATED <input type="checkbox"/>		COMPUTER GRADE <input type="checkbox"/>	FEED-THRU LUGS <input type="checkbox"/>		SUB-FEED BREAKER <input type="checkbox"/>		
			HINGED TRIM <input type="checkbox"/>		200% NEUTRAL <input type="checkbox"/>	SUB-FEED LUGS <input type="checkbox"/>		ISOLATED GND BUS <input type="checkbox"/>		
NAME	LOCATION	SOURCE	RATING (AMPS)		PHASE/ WIRE	VOLTAGE	MOUNTING	KA/IC	MODEL	NEMA TYPE
3-161-1	MECH ROOM		200A		3Ø / 4W	208Y/120	SURFACE		10 CH PRL1A	1
CKT NO.	DESCRIPTION	BREAKER	KVA LOAD				BREAKER	DESCRIPTION		CKT NO.
1	LTG 312D	20A/1P	LITG	RCPT	MOTOR	HIG	HIG	MOTOR	RCPT	LITG
3	LTG 313D TO 320D	20A/1P								2
5	LTG 322D	20A/1P	0.87							4
7	LTG 323D TO 330D	20A/1P	1.2							6
9	LTG 331D & 304D	20A/1P	0.8							8
11	LTG 302D TO 305D, 321D	20A/1P	0.86							10
13	LTG 307D TO 311D	20A/1P	0.44							12
15	RECPT RM. 306D	20A/1P								14
17	RECPT RM. 305D	20A/1P	0.9							16
19	RECPT RM. 307D	20A/1P	0.2							18
21	RECPT RM. 308D	20A/1P	0.2							20
23	FRIDGE/MICROWAVE 309D	20A/1P								22
25	RECPT RM. 309D/311D	20A/1P	0.7							24
27	RECPT RM. 312D	20A/1P	1.1							26
29	RECPT RM. 312D	20A/1P	1.1							28
31	RECPT RM. 312D	20A/1P	1.1							30
33	RECPT RM. 312D	20A/1P	0.72							32
35	RECPT RM. 313D	20A/1P	0.72							34
37	RECPT RM. 314D/315D	20A/1P	0.9							36
39	RECPT RM. 317D/318D	20A/1P	0.72							38
41	RECPT RM. 316D	20A/1P	0.9							40
LEFT SIDE SUB-TOTAL			6.2	10.14	0	0	0	0	10.32	0
RIGHT SIDE SUB-TOTAL			0	10.32	0	0				0
CONNECTED SUB-TOTAL			6.23	20.46	0	0				0
DEMAND FACTOR			1	10+5	0.8	0.8				
SUB-TOTAL			6.23	15.23	0	0				
TOTAL KVA:				21.46						
TOTAL AMPS:				59.6						

PANELBOARD SCHEDULE										NOTES:
			SE RATED <input type="checkbox"/>		COMPUTER GRADE <input type="checkbox"/>	FEED-THRU LUGS <input type="checkbox"/>		SUB-FEED BREAKER <input type="checkbox"/>		
			HINGED TRIM <input type="checkbox"/>		200% NEUTRAL <input type="checkbox"/>	SUB-FEED LUGS <input type="checkbox"/>		ISOLATED GND BUS <input type="checkbox"/>		
NAME	LOCATION	SOURCE	RATING (AMPS)		PHASE/ WIRE	VOLTAGE	MOUNTING	KA/IC	MODEL	NEMA TYPE
3-197-1	MECH ROOM		100A		3Ø / 4W	208Y/120	SURFACE		10 CH PRL1A	1
CKT NO.	DESCRIPTION	BREAKER	KVA LOAD				BREAKER	DESCRIPTION		CKT NO.
1	NEW DATA ROOM RCPT	20A/1P	LITG	RCPT	MOTOR	HIG	HIG	MOTOR	RCPT	LITG
3	JANITOR CLOSET	20A/1P								2
5	SPARE	20A/1P								4
7	SPARE	20A/1P								6
9	SPARE	20A/1P								8
11	SPARE	20A/1P								10
13	SPARE	20A/1P								12
15	SPARE	20A/1P								14
17	SPARE	20A/1P								16
19	SPARE	20A/1P								18
21	SPARE	20A/1P								20
23	SPARE	20A/1P								22
25										24
27										26
29										28
LEFT SIDE SUB-TOTAL			0.0	0	0	0	0	0	0	0
RIGHT SIDE SUB-TOTAL			0	0	0	0	0	0	0	0
CONNECTED SUB-TOTAL			0	0	0	0				0
DEMAND FACTOR			1	10+5	0.8	0.8				
SUB-TOTAL			0	0	0	0				
TOTAL KVA:			0							
TOTAL AMPS:			0.0							

PARTIAL ONE-LINE REMOVAL  
NO SCALE

PARTIAL ONE-LINE NEW WORK  
NO SCALE

REVISIONS:	DATE:
#01 - ISSUED FOR BIDDING	07.MAR.2012
#02 - ADDENDUM #1	06.APR.2012

VA WESTERN NEW YORK HEALTHCARE  
SYSTEM  
3495 BAILEY AVENUE  
BUFFALO, NY 14202

**tmm**  
architect

1898 ARCHITECTURE, DESIGN & PLANNING,  
P.C.  
444 DELAWARE AVE.  
BUFFALO, NY 14202  
P: 716.883.3516 F: 716.883.4740

CONTACTS:  
JOHN PUSZTA  
E: JPUSZTA@TMMARCHITECT.COM

**BC**  
ENGINEERING

2495 AMER ST # 318  
BUFFALO, NY 14215-0152  
P: 716.836-2315 F: 716.836-2319

CONTACTS:  
JOSHUA W. MEE (PROJECT MANAGER)  
E: JAMEE@BCENG.COM

**SE**

SEENA ENVIRONMENTAL TECHNOLOGIES,  
LLC  
350 ELMWOOD AVE.  
BUFFALO, NY 14222-2204  
P: 716.332-3134

CONTACTS:  
JOHN PUSZTA  
E: JPUSZTA@SEENAEET.COM

**IBC**

CONTACTS:  
JOSHUA W. MEE (PROJECT MANAGER)  
E: JAMEE@BCENG.COM

STAMP

CARDIOLOGY MANAGER	DATE	ENGINEERING MANAGER	DATE
INFECTION CONTROL	DATE	CARELINE MANAGER	DATE
SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE

Drawing Title: <b>PANELBOARD SCHEDULES AND PARTIAL ONE LINES</b>	
MEDICAL CENTER DIRECTOR	DATE
ASSOCIATE MEDICAL CENTER DIRECTOR	DATE

Project Title: <b>VAMC PHYSICAL THERAPY RENOVATIONS</b>		
Building Number: 1	Checked: DMG	Drawn: DMG
Location: V.A.M.C. BUFFALO, NEW YORK		

Date: 14.JAN.2011
Station Number: 628
Sheet: <b>10-107- E601</b>

