


NOTES:

1. FOR ABBREVIATIONS, GENERAL NOTES, ELECTRICAL DEMOLITION NOTES AND SYMBOL LEGEND, SEE DWG. #E-001.
2. LIGHT SOLID LINES DENOTE EXISTING EQUIPMENT TO REMAIN. DARK DASHED LINES DENOTE EXISTING EQUIPMENT TO BE DEMOLISHED.
3. WHERE ELECTRICAL WIRING SYSTEMS OR EQUIPMENT ARE SUPPORTED BY WALLS OR OTHER REMOVED, THAT IS SCHEDULED FOR DEMOLITION, RELOCATE OR RESUPPORT WIRING SYSTEMS AND/OR EQUIPMENT AS REQUIRED.

Key Notes

1. DISCONNECT AND REMOVE ALL ELECTRICAL, LIGHTING, AND FIRE ALARM SYSTEM DEVICES AND DEMOLITION WORK IN THIS AREA UNLESS OTHERWISE NOTED.
2. DISCONNECT AND REMOVE POWER TO DOOR OPERATOR.
3. DISCONNECT AND REMOVE POWER TO PNEUMATIC TUBE STATION.
4. DISCONNECT AND REMOVE POWER TO HVAC UNIT.
5. DISCONNECT AND REMOVE POWER TO CABINET UNIT HEATER.
6. PROVIDE JUNCTION BOX TO INTERCEPT EXISTING WIRING TO BE EXTENDED TO NEW DEVICE OR PROJECT AREA. REFER TO FIRE ALARM RISER DIAGRAMS.
7. REWORK JUNCTION BOX AND ASSOCIATED JUNCTION BOX TO BE ACCESSIBLE FROM FIRE DRAPER ACCESS PANEL.
8. DISCONNECT TO PANEL WIRING TO ALLOW TO DISCONNECT AND REMOVE WIRING TO ALLOW UNIT HEATER REMOVAL/REMOVE ASSOCIATED BRANCH CIRCUIT TO SOURCE OR TO FIRST DEVICE OR BRANCH CIRCUIT TO NEW UNIT HEATER LOCATION (NOT SHOWN).
10. RE-WORK CONDUIT AND WIRING SYSTEM AS REQUIRED TO RELOCATE JUNCTION BOX FROM FIELD INVESTIGATOR WIRING SYSTEM AND PROVIDE ADDITIONAL CONDUIT OR WIRING AS REQUIRED.
11. EXISTING JUNCTION BOX TO REMAIN.
12. PROVIDE EXTENSION RING TO ALLOW INSTALLATION FLUSH DEVICE BOX. REFER TO AE-101. EXTEND WIRING AS REQUIRED TO RE-INSTALL EXISTING DEVICE.
13. EXISTING FLUSH JUNCTION BOX WITH BLANK JUNCTION BOX IS NO LONGER IN SERVICE. IF REMOVE EXISTING BACKBOX AND CAP CONDUIT AT USE PROVIDE EXTENSION RING TO ALLOW INSTALLATION OF ADDITIONAL LAYER OF DRYWALL AT EXISTING FLUSH DEVICE BOX. REFER TO AE-101.


KEY PLAN




100% CD

FULLY SPRINKLERED

Project Number 541-12-103	Project Title Wade Park Renovate Medical Library - CARES	Office of Facilities Management
Building Number 1	Location Cleveland, Ohio	
Drawing Number ED-101	Date April 25, 2012	Department of Veterans Affairs
Dwg. of	Checked	



F1 FIRST FLOOR ELECTRICAL DEMOLITION PLAN
SCALE: 1/8" = 1'-0"



CONSULTANTS:

Project	Date



ARCHITECT/ENGINEERS:	925 Euclid Avenue, Suite 1900, Cleveland, Ohio 44115
Westlake Reed Leskosky	216.522.1350
	Phoenix - Washington - Cleveland
	WRL Commission #09017/00

Drawing Title FIRST FLOOR ELECTRICAL DEMOLITION PLAN	Approved Project Director
Project Title Wade Park Renovate Medical Library - CARES	Location Cleveland, Ohio
Date April 25, 2012	Checked
Dwg. of	Drawn



one eighth inch = one foot

one quarter inch = one foot

three eighths inch = one foot

one half inch = one foot

three quarters inch = one foot

one inch = one foot

one and one half inches = one foot

three inches = one foot