

ADDENDUM A

February 10, 2017

**PROJECT: Department of Veterans Affairs
MRI Renovation and Expansion
VA Long Beach Healthcare System
Long Beach, CA**

**VA Project No.: 600-CSI-101
KALA Project No: 11DVA158.35**

This Addendum reflects the revisions to project “600-CSI-101 - MRI Renovation and Expansion.” These revisions are identified as Addendum A dated 2/10/2017 on the following drawings.

DRAWINGS

These drawings have been revised to coordinate with project 600-CSI-105 being performed by VA in Building 160.

General

1. Sheet GI101:
 - A. Life Safety Plan: Revised floor plan to incorporate changes made to the building under the project 600-CSI-105 contract. The south wall of Room 116 has moved approximately 4'-0" to the south and a closet has been added between Rooms 115 and 116. Equipment and casework have been revised in Rooms 114, 115, and 116. These revisions are reflected in and apply to all general and architectural plans.
 - B. MRI Safety Zone Map revised to incorporate changes made to the building under the project 600-CSI-105 contract.
2. Sheet GC101:
 - A. Overall Phasing Plan: Revised floor plan to incorporate changes made to the building under the project 600-CSI-105 contract.
3. Sheet GC102:
 - A. Work Sequences 1, 2, 3, and 4: Revised floor plan to incorporate changes made to the building under the project 600-CSI-105 contract.



- B. Work Sequence – 3 (Phase II – Demo): Key notes have been revised to remove demolition of concrete steps, handrails, and door; and to remove construction of a new door and ramp at the south side of room 116.

4. Sheet GC103:

- A. Work Sequences 5, 6, 7, and 8: Revised floor plan to incorporate changes made to the building under the project 600-CSI-105 contract.

Civil

1. Sheet C100:

- A. Key note 2 revised.
- B. Key note 27 added.

2. Sheet C101:

- A. Building footprint revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. New concrete entry walk and graded slope removed from the southwest side of the building.
- C. Additional mow strip added along the southwest side of the building.
- D. Key note 32 removed.

Landscape

1. Sheet L-2:

- A. Building footprint revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. New concrete entry walk removed from the southwest side of the building.
- C. Key note 4 removed from southwest side of building.

2. Sheet L-4:

- A. Building footprint revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. New concrete entry walk removed from the southwest side of the building.
- C. Quantity and type of plants revised at the southwest side of the building.
- D. Shrub legend: Quantity of shrubs revised to reflect revised planting layout.

Architectural

1. Sheet AD100:

- A. Option Bids removed: new roof above electrical room, new concrete walk and ramp at southwest side of building, and demolition of existing mechanical enclosure wall.
- B. Roof layout revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- C. Key note 11 revised to remove new ramp.
- D. Key note 12 revised to remove demolition of steps.
- E. Key note 13 revised to "Not Used".
- F. Key note 28 revised to remove Option Bid.

2. Sheet AD101:

- A. Demolition plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Key notes 6 and 19 added to Rooms 115 and 116.
- C. Key note 11 revised to remove Option Bid.
- D. Key note 15 revised to remove demolition of finishes.
- E. Key notes 19 and 20: revised wording for clarity.
- F. Key note 20 removed from Room 115, and added to Rooms 112, 114, and 116.

3. Sheet AD102:

- A. Ceiling plan revised to incorporate changes made to the building under the project 600-CSI-105 contract, including ceiling grid, lighting, HVAC, and cable trays.
- B. The portion of the ceiling to be demolished was revised.
- C. Note added to legend.

4. Sheet AS100:

- A. Revised building footprint and roof layout to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. New metal canopy removed.
 - C. New concrete walk removed from the southwest side of the building.
 - D. Additional mow strip added along the southwest side of the building.
 - E. Key note 13 relocated near southwest side of the building.
 - F. Bid Option notes removed.
5. Sheet AE100:
- A. Dimensional floor plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. Dimension added from grid line B to outside face of exterior wall south of Room 116.
6. Sheet AE101:
- A. Floor plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. Key note 30 removed from Room 115.
 - C. Key note 30 added to Rooms 114 and 116.
7. Sheet AE102:
- A. Ceiling plan revised to incorporate changes made to the building under the project 600-CSI-105 contract, including ceiling grid, lighting, HVAC, and cable trays.
 - B. Omit optional specialty lighting for Room 118. Use lighting shown in detail 1 (reflected ceiling plan).
 - C. Key note 5 removed.
 - D. General note 6 revised to remove Bid Options.
 - E. General note 7 removed.
8. Sheet AE103:
- A. Crawlspace level plan revised to incorporate changes made to the building under the project 600-CSI-105 contract. New foundation walls added

where the south wall of Room 116 has moved approximately 4'-0" to the south.

9. Sheet AE104:

- A. Furniture and equipment plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.

10. Sheet AE105:

- A. Signage and wall type plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. New exterior sign removed from south wall of Room 116.
- C. Note title revised from "General Notes" to "Key Notes".
- D. Key note 2 added.
- E. Key note 2 added along gridlines 1 and 2.

11. Sheet AE201:

- A. Detail 4 (West Elevation):
 - i. Option Bid removed.
 - ii. Revised to indicate the new location of the south wall of Room 116.
 - iii. New canopy and ramp removed.
 - iv. Downspouts revised.
 - v. Gridlines revised to correct positions.
- B. General note #3 removed.
- C. Detail 3 (South Elevation):
 - i. Revised to remove new door, canopy, ramp, and signage.
 - ii. Key note 2 removed.
- D. Key note 2 revised to "Not Used."

12. Sheet AE301:

- A. Section 4:

- i. Revised to remove new door, canopy, and ramp.
- ii. Downspouts revised.

13. Sheet AE401:

- A. Detail 3 [Room 114 – (E) Technician’s Room] revised to incorporate changes made to the building under the project 600-CSI-105 contract, including casework, outlet locations, and equipment in details 3B, 3C, and 3D.
- B. Added key note 2.

14. Sheet AE601:

- A. Door 116A revised to “Not Used”.

15. Sheet AE602:

- A. EQ1 revised to “Not Used”.
- B. EQ33: location and quantity revised.
- C. EQ41: location and quantity revised.

16. Sheet AF101:

- A. Floor plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Option Bid removed.
- C. New finishes removed from Room 114 and Room 115. New finishes on north wall of Room 114 shall match existing adjacent finishes.

17. Sheet AF601:

- A. Schedule title revised to “Interior Finish Schedule”.
- B. Rooms 111, 112, 113 and 114: added to remarks column.
- C. Rooms 114 and 115: revised finishes.

Structural

1. Sheet S201:



- A. Revised foundation plan to incorporate changes made to the building under the project 600-CSI-105 contract.
- 2. Sheet S202:
 - A. Floor framing plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. New HDUs removed between gridlines 1-B and 3-B.
 - C. New HDUs removed from corners near gridlines 2-C and 3-C.
 - D. New HDU added along gridline 2 (at northeast corner of I.T. Room 126).
 - E. Detail callouts and shear wall indicators removed.
 - F. Text added to indicate which plywood shear walls are new vs. existing.
 - G. Shear wall lengths revised due to changes made to the building under the project 600-CSI-105 contract.
 - H. Plywood added between gridlines 2-A and 2-B.
- 3. Sheet S203:
 - A. Roof plan revised to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. New Simpson coil strap added along gridline B above existing RF shielding.
- 4. Sheet S301:
 - A. Detail 9:
 - i. Revised to indicate new plywood and edge nailing.
 - ii. Revised to indicate closer spacing of Simpson A35.
- 5. Sheet S304:
 - A. Detail 13 removed.

Electrical

- 1. Sheet E001
 - A. General Note 6 revised.

- B. General Note 40 added.
- 2. Sheet EPD101
 - A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. Key note 10 called out on (E) Panel Board “B”.
 - C. Key note 10 revised.
 - 3. Sheet EPD102
 - A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. Key note 10 revised.
 - C. Panel Boards “B” and “C” identified as (E).
 - 4. Sheet EP101
 - A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. FC-1 circuit number revised.
 - C. Location of existing Panel Boards “B” and “C” indicated.
 - 5. Sheet EP102:
 - A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
 - B. Room 118: RF filter circuit number revised.
 - C. Key note 22 and data gutter removed in plan.
 - D. Key note 22 revised to “Not Used”.
 - E. FC-1 circuit number revised.
 - F. General note 11 revised.
 - G. Key note 10 revised.
 - 6. Sheet EP102-a:
 - A. Room 118: RF filter circuit number revised.

7. Sheet EP103:

- A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Room 102: Medical Gas Alarm Panel circuit number revised.
- C. Room 118: RF filter circuit number revised.
- D. 42" callout and data gutter removed from plan.
- E. Key note 28 revised to "Not Used".
- F. FC-1 circuit number revised.
- G. General note 10 revised.
- H. Key note 10 revised.

8. Sheet EP104:

- A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Room 102: Medical Gas Alarm Panel circuit number revised.
- C. Room 118: RF filter circuit number revised.
- D. Key note 28, 42" callout, and data gutter removed in plan.
- E. Key note 28 revised to "Not Used".
- F. FC-1 circuit number revised.
- G. General note 10 revised.
- H. Key note 10 revised.

9. Sheet EP105:

- A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Circuit numbers revised for EF-3, EF-4, and HP-5.

10. Sheet EP106:

- A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.

- B. Circuit numbers revised for EF-3, EF-4, and HP-5.

11. Sheet EL102:

- A. Revised power plan to incorporate changes made to the building under the project 600-CSI-105 contract.
- B. Details 2 and 3 removed.
- C. Exit light and exterior light fixture Type M removed.

12. Sheet E401:

- A. (N) Distribution Board “MSL” Load Calculations: revised load for Panel Boards “B”, “C”, and “MSL”.
- B. Single line diagram (Remodel) revised for Panel Board “B”.
- C. Demolition key note 3 revised.
- D. Remodel key note 3 revised.
- E. Single line diagram (Demolition) revised for Panel Boards “B” and “C”.

13. Sheet E601:

- A. Schedule for panel board “B” revised, including total load.
- B. Calculations revised for (N) Panel Board “B”.
- C. Light Fixture Schedule: light fixtures O and P removed.
- D. General notes 1, 2, 3, and 4 added.

END OF ADDENDUM A