

Chilled Beam Required Capacities					
Cooling Primary Air Temperature: (55 F)			Heating Primary Air Temperature: (70 F)		
GPM	CFM	Capacity BTUH	GPM	CFM	Capacity BTUH
0.5	30	1,600	0.5	30	2,698
	33	1,867		33	2,693
	35	2,350		35	2,944
	55	3,100		55	3,669
1	65	3,600	0.5	65	3,647
	55	3,550		55	3,155
1.25	70	4,400	0.5	70	4,022
	80	4,700		80	4,156
	85	4,732	0.75	85	4,622
2	65	4,300	0.5	65	3,647