

NOTES:

GENERAL NOTES

A. REFER TO SHEET M-001 FOR GENERAL NOTES, ABBREVIATIONS, AND SYMBOL LEGEND.
B. REFER TO SHEET M-601 FOR SCHEDULES.
C. ALL HTWS/R PIPING SHALL BE 3/4" UNLESS NOTED OTHERWISE.
D. PROVIDE BALL-TYPE SHUT-OFF VALVES AT ALL HTWS/R BRANCH TAKE-OFFS FROM MAIN HTWS/R LOOP.
E. COORDINATE AND REFER TO ARCHITECTURAL PLANS FOR PROJECT DEDUCT ALTERNATES.

KEY PLAN NTS — NORTH

100% CD

FULLY SPRINKLERED

Revisions:	Date

CONSULTANTS:

STATE OF OHIO — PROFESSIONAL ENGINEER

ARCHITECT/ENGINEERS:

Westlake Reed Leskosky

925 Euclid Avenue, Suite 1900, Cleveland, Ohio 44115

216.522.1350

Phoenix - Washington - Cleveland
WRL Commission #09017.00

Drawing Title: **FIRST FLOOR SOUTH HVAC PIPING PLAN**

Approved: Project Director

Project Title: Wade Park Renovate Medical Library - CARES

Location: Cleveland, Ohio

Date: April 25, 2012 | Checked | Drawn

Project Number: 541-12-103

Building Number: 1

Drawing Number: **MP-101**

Dwg. of

Office of Facilities Management

Department of Veterans Affairs

VA FORM 08-6231, OCT 1978