

HOT WATER RECIRCULATING PUMP SCHEDULE								
MARK	DESCRIPTION	GPM	TOTAL HEAD FT.	HP	ELECTRICAL			REMARKS
					VOLTS	PHASE	HERTZ	
HWSP-1	HOT WATER RECIRCULATING PUMP-1	5.0	10.0	33	115	1	60	BELL & GOSSETTE MODEL #WR-33
HWSP-2	HOT WATER RECIRCULATING PUMP-2	20.0	10.0	33	115	1	60	BELL & GOSSETTE MODEL #WR-33


RECORD DRAWINGS

DATE: NOVEMBER 16, 2012

THESE AS-BUILT DOCUMENTS HAVE BEEN PREPARED BASED ON INFORMATION PROVIDED BY THE CONTRACTOR LOUISIANA GENERAL CONTRACTORS, LTD. THE ARCHITECT/ ENGINEER HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS THAT MAY BE INCORPORATED AS RESULT OF INCORRECT INFORMATION PROVIDED BY THE CONTRACTOR.

CONSULTANTS:

TEXAS REGISTERED
ENGINEERING FIRM F-10487
700 N. ST. MARY'S
SUITE 1225
SAN ANTONIO, TX 78205
WWW.RGMENGINEERING.NET
PHONE: 210.299.4522
FAX: 210.299.4525

 1617 E. COMMERCE ST., SUITE 7102, SAN ANTONIO, TEXAS 78205 USA
210 . 530 . 0755 FAX: 210 . 530 . 9427

These documents can not be copied or reproduced without written consent from
WestEast Design Group

Approved: Project Director

Location	
Audie L. Murphy Memorial Veterans Hospital San Antonio, Texas	
Date	Checked Drawn
28 JULY 2010	

Office of
Facilities
Management

 Department of
Veterans Affairs