


RFI FORM**Contractor Name: D2 Construction LLC****Address: 107 W. Sahuaro Street****Phone/Fax: (520) 748-9371 / (888) 543-8500****Send to: cecil.nichols@va.gov**

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	600-CSI-101	RFI NO.:	002
PROJECT NAME:	MRI Renovation & Expansion	DATE REQUESTED:	03/29/2017
SOLICITATION NO.:	VA262-17-B-0095	REFERENCE:	Construction Scope, Item 3
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>RFP page 6, Construction Service Scope, Item #3 states "items identified as customer / owner provided items shall be provided by the contractor awarded this construction contract." This is a very confusing statement. What is being said with this sentence? Will the Contractor be able to rely on the CFCI, GFCL, and GFGL designations found on Sheet AE602 – Equipment Schedule?</p>			
PROJECT MANAGER'S RESPONSE			
<p>KAL Response (4/3/17): "Items identified as customer / owner provided items shall be provided by the contractor awarded this construction contract" means the items indicated as customer or owner provided in the GE Drawings are to be provided by the contractor who is awarded in response to this solicitation VA262-17-B-0095.</p> <p>The only separate contractor is the GE contractor. See attached sketch (revised drawing sheet A602 Addendum B), where the clouded equipment has been revised to GFGL or CFCI as indicated.</p> <p>Contractor shall review all drawings to bid this project. Also refer to sheet GC102, which identifies MRI Equipment Pre-Installation Requirements.</p>			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 4/3/17	