

KEY NOTES:

- A

NONSPRINKLED ELECTRICAL ROOM  
PER SECTION 8.15.10.3 OF NFPA 13.
- B

MAXIMUM 49 OCCUPANTS.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- HORIZONTAL EXIT PASSAGEWAY
- EXIT
- EXIT PASSAGEWAY
- LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR – WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR – NO SMOKE DETECTION REQUIRED
- EXIT STAIR OR PASSAGEWAY
- SPRINKLER/FIRE ALARM ZONE
- MANUAL PULL STATION
- FIRE EXTINGUISHER

BUSINESS OCCUPANCY  
TYPE II (222)  
CONSTRUCTION



EX

STORAGE OCCUPANCY  
TYPE II (000)  
CONSTRUCTION

BUILDING 3 BASEMENT FLOOR

BUILDING 3 FIRST FLOOR  
BUSINESS OCCUPANCY

FULLY SPRINKLERED  
MIXED OCCUPANCY

Revisions		Date	 <div>Dept. of Veterans Affairs Health Care Center 2300 Ramsey St. Fayetteville, NC 28301</div>	 <div>FIRE PROTECTION &amp; CODE CONSULTANTS, LLC 1520 MAIN STREET INDIANAPOLIS, IN 46224 (317)406-5188</div>	Drawing Title <div>BUILDING 3 BASEMENT</div>	Client Project No.	Contract No.	Project Title <div>STATEMENT OF CONDITIONS</div>	Designed By FVO	Checked By FVO	Drawn By DN	Date 12/27/16	Drawing No. <div>SOC-1</div> <div>Sht. 2 Of 3</div>
FP&C Proj.#:		1694.14				Building No. MAIN	AutoCAD File Name SOC01 3-B, 1		Location VA HEALTH CARE CENTER FAYETTEVILLE, NORTH CAROLINA	Scale: NO SCALE			