

SUITE DESCRIPTIONS

SUITE NUMBER	SUITE NAME	SUITE SIZE	TYPE OF SUITE	EXIT NUMBER
1	DENTAL SUITE	3,235 Sq. Ft.	NON SLEEPING PATIENT CARE	2
2	DENTAL/ARC SUITE	3,145 Sq. Ft.	NON SLEEPING PATIENT CARE	2
3	CARDIOLOGY SUITE	1,895 Sq. Ft.	NON SLEEPING PATIENT CARE	1
4	AUDIO/SPEECH SUITE	2,600 Sq. Ft.	NON SLEEPING PATIENT CARE	2

KEY NOTES:

- 1 SPRINKLERS LOCATED ABOVE AUDIO BOOTHS.
- 2 SPRINKLER LOCATED ABOVE COOLERS.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- HE

HORIZONTAL EXIT PASSAGEWAY
- EX

EXIT
- EP

EXIT PASSAGEWAY
- LC

LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR – WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR – NO SMOKE DETECTION REQUIRED
- EXIT STAIR OR PASSAGEWAY
- SPRINKLER/FIRE ALARM ZONE
- F

MANUAL PULL STATION
- FIRE EXTINGUISHER

BUILDING 1 BASEMENT FLOOR NORTH

FULLY SPRINKLERED
BUSINESS OCCUPANCY

Revisions		Date		Dept. of Veterans Affairs Health Care Center 2300 Ramsey St. Fayetteville, NC 28301		FIRE PROTECTION & CODE CONSULTANTS, LLC 1520 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188	Drawing Title	Client Project No.	Contract No.	Project Title		Designed By	Checked By	Drawn By	Date	Drawing No.
FP&C Proj.#:		1694.14					BUILDING 1 BASEMENT FLOOR NORTH	Building No. MAIN	AutoCAD File Name SOC01,02 1-B	STATEMENT OF CONDITIONS		FVO	FVO	DN	12/27/16	Location VA HEALTH CARE CENTER FAYETTEVILLE, NORTH CAROLINA