

KEY NOTES:

- A

MAXIMUM 49 OCCUPANTS.
- B

EXISTING DEAD-END CORRIDORS
PERMITTED PER SECTION 19.2.5.2 OF
NFPA 101-2015.
- C

FIRE SPRINKLERS INSTALLED PER
CEILING MOUNTED OBSTRUCTION SPACING
REQUIREMENTS OF TABLE 8.6.5.1.2 OF
NFPA 13-2013 EDITION.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- HE

HORIZONTAL EXIT PASSAGEWAY
- EX

EXIT
- EP

EXIT PASSAGEWAY
- LC

LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR – WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR – NO SMOKE DETECTION REQUIRED
- EXIT STAIR OR PASSAGEWAY
- SPRINKLER/FIRE ALARM ZONE
- F

MANUAL PULL STATION
- FIRE EXTINGUISHER

