

KEY NOTES:

- A

MAXIMUM 49 OCCUPANTS.
- B


EXISTING DEAD-END CORRIDORS PERMITTED PER SECTION 19.2.5.2 OF NFPA 101-2015.
- C

FIRE SPRINKLERS INSTALLED PER FLOOR MOUNTED OBSTRUCTION SPACING REQUIREMENTS OF TABLE 8.6.5.2.2 IN NFPA 13-2013 EDITION.
- D

KITCHEN RANGE FIRE SUPPRESSION AND SPRINKLER RESISTIVE ENCLOSURE PER SECTION 18.3.2.5.2 OF NFPA 101-2006 EDITION. DESIGN PRIOR TO REQUIREMENT AND NO ENCLOSURE PROVISIONS NOW FOUND IN SECTION 18.3.2.5.3 OF NFPA 101-2015 EDITION.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- HORIZONTAL EXIT PASSAGEWAY
- EXIT
- EXIT PASSAGEWAY
- LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR – WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR – NO SMOKE DETECTION REQUIRED
- EXIT STAIR OR PASSAGEWAY
- SPRINKLER/FIRE ALARM ZONE
- MANUAL PULL STATION
- FIRE EXTINGUISHER



BUILDING 1 FOURTH FLOOR

FULLY SPRINKLERED
HEALTH CARE OCCUPANCY

Revisions		Date	 <div>Dept. of Veterans Affairs Health Care Center 2300 Ramsey St. Fayetteville, NC 28301</div>	 <div>FIRE PROTECTION & CODE CONSULTANTS, LLC 1501 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188</div>	Drawing Title	Client Project No.	Contract No.	Project Title	Designed By	Checked By	Drawn By	Date	Drawing No.
FP&C Proj. #:		1694.14			BUILDING 1 FOURTH FLOOR	Building No. MAIN	AutoCAD File Name SOC08 1-4	STATEMENT OF CONDITIONS	FVO	FVO	DN	12/27/16	SOC-8
													Sht. 9 of 10
									Location VA HEALTH CARE CENTER FAYETTEVILLE, NORTH CAROLINA		Scale: NO SCALE		