


KEY NOTES:

- A** LINEN CHUTE VENT SIZE.
- B** EXISTING DEAD-END CORRIDORS PERMITTED PER SECTION 19.2.5.2 OF NFPA 101-2015.
- C** MAXIMUM 49 OCCUPANTS.
- D** SEE EQUIVALENCY FOR OVERSIZED PROTECTIVE PLATE.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- HE** HORIZONTAL EXIT PASSAGEWAY
- EX** EXIT
- EP** EXIT PASSAGEWAY
- LC** LINEN CHUTE
- SUITE DESIGNATIONS
- AREA OPEN TO CORRIDOR - WITH SMOKE DETECTION
- AREA OPEN TO CORRIDOR - NO SMOKE DETECTION REQUIRED
- EXIT STAIR OR PASSAGEWAY
- SPRINKLER/FIRE ALARM ZONE
- F** MANUAL PULL STATION
- FIRE EXTINGUISHER



BUILDING 1 FIFTH FLOOR

FULLY SPRINKLERED  
HEALTH CARE OCCUPANCY

Revisions		Date	 <div>Dept. of Veterans Affairs Health Care Center 2300 Ramsey St. Fayetteville, NC 28301</div>	 <div>FIRE PROTECTION &amp; CODE CONSULTANTS, LLC 1501 MAIN STREET INDIANAPOLIS, IN 46224 (317)486-5188</div>	Drawing Title	Client Project No.	Contract No.	Project Title <b>STATEMENT OF CONDITIONS</b>	Designed By FVO	Checked By FVO	Drawn By DN	Date 12/27/16	Drawing No. <b>SOC-9</b> Sht. 10 Of 10
FP&C Proj.#:		1694.14			<b>BUILDING 1 FIFTH FLOOR</b>	Building No. MAIN	AutoCAD File Name SOC09 1-5		Location VA HEALTH CARE CENTER FAYETTEVILLE, NORTH CAROLINA	Scale: NO SCALE			