

Summary of Addendum 1, dated 14 May 12
Normal Power Substation 537-11-144

Drawing 537-1C-AS-101 First Floor Plan:

Base to be provided at existing first floor corridor to match existing. Detail 4 adjusted as no base exists in room 103 per schedule

Drawing 537-1C-E0-001 Electrical Symbols and Abbreviations

Type F5 lighting fixture not used and deleted, the other lighting fixtures include a more detailed description

Drawing 537-1C-EL-101 First Floor Lighting Plan

Note 10 referenced in plan, fire alarm connection details added in note 3, additional identification tags added to two receptacles.