



1 ELECTRICAL SITE PLAN - DEMOLITION 4

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot

- GENERAL NOTES:**
- EXISTING UTILITY INFORMATION WAS OBTAINED FROM RECORD DRAWINGS. ELECTRICAL CONTRACTOR SHALL FIELD VERIFY EXISTING CONDITIONS PRIOR TO COMMENCEMENT OF WORK.
 - COORDINATE ALL POWER OUTAGES WITH OWNER PRIOR TO CUTTING ANY SERVICE, CONDUIT OR CABLE. OUTAGES SHALL BE KEPT TO AN ABSOLUTE MINIMUM.
 - EXISTING UTILITIES DAMAGED DURING WORK BEING PERFORMED FOR THIS PROJECT SHALL BE REPAIRED OR REPLACED AT CONTRACTOR'S EXPENSE.
 - THE ELECTRICAL CONTRACTOR SHALL SUBMIT A COMPLETE SCHEDULE OF CONSTRUCTION TO THE VA INDICATING THEIR PROPOSED DATES AND DURATIONS FOR ALL OUTAGES REQUIRED. OUTAGES SHALL TAKE PLACE ON THE WEEKENDS. OUTAGE SHALL START FRIDAY AT 1730 HOURS AND BE COMPLETED BY SUNDAY AT 2400 HOURS.
 - THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR ALL REQUIRED EXCAVATION, SHORING REMOVAL AND BACKFILL TO PERFORM THE WORK INDICATED.
 - ALL REQUESTS FOR OUTAGES SHALL BE DONE IN WRITING TO THE VA. ALL OUTAGES MUST BE REQUESTED A MINIMUM OF 14 WORKING DAYS PRIOR TO THE SCHEDULED OUTING.
 - NO SPLICES IN SYSTEM. SPLICES IN PRIMARY OR SECONDARY SYSTEM ARE NOT ALLOWED.

- KEYED NOTES:**
- EXISTING OIL SWITCH AND CONCRETE PAD TO BE REMOVED.
- 1 DISCONNECT AND REMOVE ALL FEEDERS. REMOVE INSULATING LIQUID AND PROVIDE CERTIFICATE OF DISPOSAL TO COTR.
- 2 EXISTING GAS SWITCH AND CONCRETE PAD TO BE REMOVED. DISCONNECT AND REMOVE ALL FEEDERS.
- EXISTING TRANSFORMER AND CONCRETE PAD TO BE REMOVED.
- 3 DISCONNECT AND REMOVE ALL FEEDERS BACK TO SWITCH. REMOVE INSULATING LIQUID AND PROVIDE CERTIFICATE OF DISPOSAL TO CONTRACTING OFFICER'S TECHNICAL REPRESENTATIVE. SEE NEW WORK DRAWINGS FOR ADDITIONAL REQUIREMENTS.
- 4 EXISTING CAMPUS LOOP DISTRIBUTION DUCT BANKS SHALL REMAIN.

ALL TRANSFORMERS, GAS SWITCHES AND OIL SWITCHES THAT ARE IDENTIFIED ON THIS SITE PLAN SHALL BE REMOVED AND REPLACED UNLESS OTHERWISE NOTED.

CONSULTANTS:		ARCHITECT/ENGINEERS:		Drawing Title ELECTRICAL SITE PLAN - DEMOLITION		Project Title REPLACE OIL SWITCH		Project Number # 595-11-134		Office of Construction and Facilities Management 			
								Building Number ---					
								Drawing Number E2					
Revisions				Approved Project Director		Location 1700 South Lincoln Ave - Lebanon, PA 17042		Date 05/02/2012		Checked SK		Drawn TA	

VA FORM 08-6231