


RFI FORM**Contractor Name: D2 Construction LLC****Address: 107 W. Sahuaro Street****Phone/Fax: (520) 748-9371 / (888) 543-8500****Send to: cecil.nichols@va.gov**

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:	600-CSI-101	RFI NO.:	005
PROJECT NAME:	MRI Renovation & Expansion	DATE REQUESTED:	04/05/2017
SOLICITATION NO.:	VA262-17-B-0095	REFERENCE:	Carbon Filters
DRAWING:	M001	SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
<p>Please be specific as possible:</p> <p>Per General Note 1 on drawing M001, we are to provide "carbon filters in all existing HVAC in MRI & vicinity HVAC in Linear Accelerator Building". In order for all Contractors to bid the same scope of work, please provide complete schedule for these filters.</p>			
PROJECT MANAGER'S RESPONSE			
<p>Contractor to provide same size carbon filters as existing pre-filters in the existing HVAC Units. These carbon filters shall be installed as a pre-filter in existing HVAC Units during construction to prevent intrusion of fumes during construction.</p> <p>Himansu Shah, PE TTG 4/10/17</p>			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: 		DATE: 4/10/2017	