

**RFI FORM**

**Contractor Name:** Claymore Development LLC  
**Address:** 112 Water Street, Suite 107, Henderson NV 89015  
**Phone/Fax:** (702) 747-2888 / (702) 852-0336  
**Send to:** cecil.nichols@va.gov

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	600-CSI-101	<b>RFI NO.:</b>	011- Rev. A
<b>PROJECT NAME:</b>	MRI Renovation & Expansion	<b>DATE REQUESTED:</b>	04/11/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-0095	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: 1 – Where is laydown area located in relation to the MRI Bldg 160? A) Do we have room for an on-site office? B) Do we need porta-Johns? C) Is there power available? D) Is there a landline available?			
<b>PROJECT MANAGER'S RESPONSE</b>			
A) The contractor will have room for onsite office. B) Temporary toilets shall be provided by the contractor for his staff. See Specification 01 00 00 General Requirements, section 1.19. C) See Specification 01 00 00, General Requirements, section 1.20. Availability and use of utilities. Electric power may not be available. The contractor shall provide his own generator to supply power. D) Landline is not available.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER</b> <i>Syed Ehsan</i> SYED EHSAN		<b>DATE:</b> 4/15/17	