

FORM P-2

Boiler No. T3174-1-2 (Mfr's. Serial No.) (CRN) 270-03460 (Drawing No.) 18566 (Nat'l Board No.)

15. Openings: (a) Steam 1-8" 300 # FLANGE (b) Pressure Relief 3-3" NPT
(No., Size, and Type) (No., Size, and Type)
(c) Blowoff 2-2" 300# FLANGE BOTTOM CL (d) Feed 2-2" NPT R & L SIDE
(No., Size, Type, and Location) (No., Size, Type, and Location)
(e) Manholes: No. 1 Size 12" X 16" Location TOP CL
(f) Handholes: No. 6 Size 3.25" X 4.5" Location SHELL

16. Fusible Plug (if used) N/A (No., Diameter, Location, Mfr's Stamp)

17. Boiler Supports: No. 4 Type SADDLES Attachment WELDED
(Saddles, Legs, Lugs) (Bolted or Welded)

18. MAWP 150 PSI Based On PG 46 Heating Surface 3000 SQ. FT.
(Code Par. and/or Formula) (Total)

19. Shop Hydrostatic Test 225 PSI 20. Maximum Designed Steaming Capacity 20700 LBS/HR

21. Remarks -

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this data report are correct and that all details of design, material, construction, and workmanship of this boiler conform to Section I of the ASME BOILER AND PRESSURE VESSEL CODE.

Our Certificate of Authorization no. 10,221 to use the (S) S Designator expires 11-21-14

Date 12-4-13 Signed [Signature] Name CLEAVER BROOKS
(Authorized Representative) (Manufacturer)

CERTIFICATE OF SHOP INSPECTION

Boiler constructed by CLEAVER BROOKS at THOMASVILLE, GA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by HSBCT

_____ have inspected parts of this boiler referred to as data items 6,7,9-11,13,15,17-20

_____ and have examined Manufacturer's Partial Data reports for items _____

NONE and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with Section I of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 12-4-13 Signed [Signature] Commissions NB9412 "A" GA00113
(Authorized Inspector) (National Board Commission Number and Endorsement)

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of this boiler conforms with the requirements of Section I of the ASME BOILER AND PRESSURE VESSEL CODE.

Our Certificate of Authorization no. _____ to use the (A) or (S) _____ symbol expires _____

Date _____ Signed _____ Name _____
(Authorized Representative) (Assembler)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the state or province of _____ and employed by _____

_____ have compared statements in this Manufacturer's Data Report with the described boiler and state that the parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this described in this Manufacturer's Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commissions _____
(Authorized Inspector) (National Board Commission Number and Endorsement)