



- SECOND LEVEL LIGHTING PLAN NOTES:**
- ① TYPICAL: TYPE "A" AND "B" FIXTURES SHALL BE STEM MOUNTED AT ENDS WITH 45-DEGREE SWIVEL CEILING CANOPY. STEM LENGTH AS REQUIRED SO BOTTOM OF FIXTURE TO BE LEVEL WITH BOTTOM OF CEILING JOIST. PROVIDE CEILING JUNCTION BOX WITH FLEX CONDUIT FEED TO FIXTURE.
 - ② TYPICAL: TYPE "AE" AND "BE" FIXTURES SHALL BE SAME AS TYPE "A" AND "B", EXCEPT WITH INTEGRAL BATTERY PACK TO POWER ONE LAMP WITH 1100 TO 1400 LUMENS DURING EMERGENCY. CONNECT BATTERY PACK TO UNSWITCHED CIRCUIT HOT WIRE.
 - ③ TYPICAL: TYPE "CE" FIXTURES SHALL HAVE INTEGRAL BATTERY PACK TO POWER ONE LAMP WITH 1100 TO 1400 LUMENS DURING EMERGENCY. CONNECT BATTERY PACK TO UNSWITCHED CIRCUIT HOT WIRE.
 - ④ TYPICAL: MOUNT EMERGENCY EXIT SIGN ON BOTTOM OF CEILING JOIST.
 - ⑤ TYPICAL: MOUNT DOUBLE FACE EMERGENCY EXIT SIGN ON BOTTOM OF CEILING JOIST, WITH DIRECTIONAL ARROWS AS INDICATED.
 - ⑥ RUN ONE 1" C WITH 4#10 + 1#10 GROUND TO LIGHTING JUNCTION BOX IN GROUND LEVEL ELEVATOR LOBBY.
 - ⑦ RUN ONE 1" C WITH 4#10 + 1#10 GROUND TO LIGHTING JUNCTION BOX IN GROUND LEVEL STAIRWELL.
 - ⑧ 1-1/4" C WITH 7#10 + 1#10 GROUND WITH LIGHTING CIRCUITS FROM GROUND LEVEL.
 - ⑨ 1-1/4" C WITH 7#10 + 1#10 GROUND WITH LIGHTING CIRCUITS TO THIRD LEVEL.
 - ⑩ 1" C WITH 4#10, 1#10 (UNSWITCHED #8 HOT LEG) + 1#10 GROUND. CONNECT EXIT SIGNS AND EMS BATTERY PACKS ON UNSWITCHED #8 HOT LEG NOT CONTROLLED BY LCP. ALL DOWNSTREAM BRANCH CIRCUIT WIRING SHALL ALL BE #10, MINIMUM 1" C.

NORTH

Second Level Floor Lighting Plan
 1/8" = 1'-0"

CONSTRUCTION DOCUMENTS - FINAL SUBMISSION

Revisions: 1 2 3 4 5 6 7 8 9	CONSULTANTS: 	ARCHITECT/ENGINEERS:   Civil • Structural • Design • Construction 895 W. Ashlan Ave. Clovis, CA 93612 TEL: (559) 346-0800 FAX: (559) 346-0900 EFRAMPTON@FCE-ENG.COM	Drawing Title: Second Level Floor Lighting Plan	Project Title: VA Northern California Health Care System Parking Structure	Project Number: 612-CSH-102	Office of Construction and Facilities Management 	
	Approved: Project Director	Location: 10535 Hospital Way, Mather, CA 95655	Building Number: -	Drawing Number: E221	Date: 05/19/2011		Checked: PK