

**AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT**

BPA NO.

1. CONTRACT ID CODE

PAGE  
1OF PAGES  
52. AMENDMENT/MODIFICATION NUMBER  
A000043. EFFECTIVE DATE  
04-21-2017

4. REQUISITION/PURCHASE REQ. NUMBER

5. PROJECT NUMBER (if applicable)  
675-12-1016. ISSUED BY  
CODE  
Department of Veterans Affairs  
Network Contracting Office 8 (NCO 8)  
for Orlando VA  
8875 Hidden River Pkwy Suite 525  
Tampa FL 33637

36C673

7. ADMINISTERED BY (If other than Item 6)

CODE  
36C673Department of Veterans Affairs  
Network Contracting Office 8 (NCO 8)  
for Orlando VA  
8875 Hidden River Pkwy  
Tampa FL 33637

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

VA248-17-R-0063

X

9B. DATED (SEE ITEM 11)

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS** The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. 5/19/2017 NLT 12:00PM EST

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

SEE CONTINUATION PAGES

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Tiffany Garfield

NCO815L2-71061

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

BY

(Signature of Contracting Officer)

PREVIOUS EDITION NOT USABLE

STANDARD FORM 30 (REV. 11/2016)  
Prescribed by GSA - FAR (48 CFR) 53.243

The purpose of this Amendment is to a) Revise the VA response to RFI #12 from Set #2 from Amendment A00003, dated 4-18-2017; b) Incorporate the sign in sheet from the first site visit dated 3-30-2017; c) Announce a Site Visit Date and Time; d) Extend the RFI response date; and e) Extend the Proposal due date.

- a) Revise the VA response to RFI #12 from Amendment A00003, Set #2 dated 4-18-2017:

RFI #12 question and answer originally from RFI Set #2 is changed from:

12. Does the VA expect us to provide temporary generator power during any of the outages necessary to install the new ATS switches?

***Response: All shutdowns must be scheduled and completed during off-work hours, including weekends.***

Is changed to read:

12. Does the VA expect us to provide temporary generator power during any of the outages necessary to install the new ATS switches?

***Response: Pharmacy, SPS, Operating rooms, and MRI areas must not lose cooling or humidity control for more than 30 minutes during any power outage of this project.***

- ***Pharmacy- AHU 5A and 9A fed from panel NHA2 in room A113. FP&L Chiller fed from MDP-1 in chiller yard.***
- ***Operating Rooms AHU 5C and 6C fed from panel NHCA, NHCB, and EQHC in room C127. OR Chiller fed from panel EQDP or as a back-up from FP&L Chiller fed from MDP-1 in chiller yard.***
- ***SPS AHU 7C fed from panel NHCA, NHCB, and EQHC in room C127. OR Chiller fed from panel EQDP or as a back-up fed from FP&L Chiller fed from MDP-1 in chiller yard.***
- ***MRI- AHU 1 and AHU 2 fed from panel NHG. FP&L chiller fed from MDP-1 in chiller yard.***

***Pharmacy, MRI, and Pathology Lab must not lose critical power for more than 60 minutes. Fed from ATS-Critical.***

*All shutdowns must be scheduled and completed during off-work hours, including weekends. It is the responsibility of the contractor to ensure these timeframes are strictly adhered to. Whenever any of the areas listed above are involved in an outage, the contractor will be required to submit a written plan for the outage that meets these criteria to be approved by COR. The contractor shall come up with means and methods to adhere to these time frames during outages weather portable generators are used, equipment is refed from alternate panels, work is conducted within timeframe etc. A contingency plan must also be included in the written outage plan for approval. No electrical hot work will be permitted.*

b) Incorporate the sign in sheet from the first site visit dated 3-30-2017:

See attached sign in sheet (2 pages)

c) Announce a Site Visit Date and Time:

The VA has scheduled a second site visit on Wednesday, April 26, 2017 at 10:00 a.m. EST. All interested contractors shall meet at the Engineering Conference Room D211, at the Orlando VA Medical Center Outpatient Clinic, 2900 Veterans Way, Orlando, Florida 32940.

d) Extend the RFI response date:

All RFIs are due no later than 12:00pm EST on May 5, 2017

e) Extend the Proposal due date:

Proposals are now due no later than 12:00pm EST on May 19, 2017

See attached document: Generator Preproposal sign in - Site Visit 3-30-17.

# INSTALL STAND BY GENERATOR

## Pre-proposal Site Visit

3/30/17

NAME	COMPANY	TELEPHONE	E-MAIL
Paul Conrad	Blue Cord Design & Const.	407-758-8544	pconrad@blue-cord.com
Michael Waldrop	Blue Cord Design & Construction	407 425 1790	mwaldrop@blue-cord.com
Timothy Sheldon	Native American Pride Const.	(863)430-8342	TSheldon@NapConstructors.com
Scott Nelszwer	GREENLAND ENTERPRISES	757 771 0307	SNelszwer@greenlandenterprises.com
Anthony Williams	SAW CONTRACTING	757 320 3448	AWilliams@SAWCONTRACTING.COM
Jennifer Hallam	Abrams Group	813 997 8787	jenniferh@prtree.com
Pete Fernandez	Abrams Group	813 503-5292	pete@prtree.com
JOE GROSSMAN	Tampa Bay ELECTRIC INC	727-815-1164	jogrossman.tampabayelectric@verizon.net
ASHLEY GALETTI	L&J BUILDING CO.	810-550-4557	ASHLEY@LJBCO.NET
William Matthews	Wire Supply Inc	321-631-9914	WMatthews@wire-supply-inc.com
Natasha Cooper	Milicon Inc.	951-744-9313	nabasha@milicon.us
Anthony Cooper	Milicon Inc	5616326224	anthony@milicon.us
Al Brantner	Milicon Inc	"	"
Justin Gattuso	Venergy Group	772-318-9312	justin@venergygroup.com
DEIR PALMA	Venergy Group	772-263 3226	Opalma249@gmail.com
Dave Garry	Cummins, Inc.	407-535-4916	dave.garry@cummins.com
MARC MYERS	CUMMINS, INC.	407-908-2493	Marc.Myers@Cummins.com
BILL NIKKILA	A VET COMMUNICATIONS, INC	847-762-9185	BN@AVETCOMMUNICATIONS.COM
John Griffiths	RF Yates Electric	407-600-7697	JohnGriffis@REYatesElectric.COM

