


**RFI FORM****Contractor Name: BVB Construction****Address: 1650 Palma Drive, Ventura CA****Phone/Fax: (805) 642-8381 / (805) 642-8382****Send to: cecil.nichols@va.gov**

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	600-CSI-101	<b>RFI NO.:</b>	032
<b>PROJECT NAME:</b>	MRI Renovation & Expansion	<b>DATE REQUESTED:</b>	04/13/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-0095	<b>REFERENCE:</b>	new manhole installation
<b>DRAWING:</b>	ES101	<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible: There is indication there may be conduit heading to the direction of the new MH-3 installation. Please verify there will be no duct banks of low voltage, medium voltage or any other underground utilities that may interfere with the installation of the new manhole?</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p><b>IMEG Response:</b> Per site visit with VA Engineers and Electricians to verify the existing condition, there were no other underground duct banks heading to manhole MH-3. But prior to start working, contractor shall verify existing condition per General Note 5 on Sheet ES101.</p> <p><i>Arnel Caparros - IMEG</i> 4/19/2017</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b> 		<b>DATE:</b> 04/21/2017	