



1 SECOND FLOOR PLAN  
1/8" = 1'-0"

- DEMOLITION NOTES:**
1. DISCONNECT AND REMOVE ALL EXISTING EXHAUST DUCTWORK TO CHASE. NOTE-ALL DUCTS SHOWN ARE DIAGRAMMATIC.
  2. DISCONNECT AND REMOVE STEAM RADIATORS AND ASSOCIATED TRAPS AND CONTROLS (TYP. OF ALL IN WARD B)
- GENERAL NOTES:**
1. HVAC CONTRACTOR SHALL RENSULATE EXISTING STEAM LINES IN WARD 'B' WHERE ASBESTOS CONTAINING INSULATION WAS REMOVED BY THE ASBESTOS ABATEMENT CONTRACTOR. REFER TO ASBESTOS DRAWINGS LOCATIONS AND QUANTITIES.



KEY PLAN  
N/S



Revisions	Date
100% Submission	7/02/10
90% Submission	5/27/10
60% Submission	4/28/10

VA WESTERN NEW YORK HEALTHCARE SYSTEM  
3495 BAILEY AVENUE  
BUFFALO, NEW YORK 14215



Architect stamp


CARDIOLOGY	DATE	ENGINEERING MANAGER	DATE
INFECTION CONTROL	DATE	CARELINE MANAGER	DATE
SAFETY OFFICER	DATE	CHIEF OF STAFF	DATE

ASSOCIATE MEDICAL CENTER DIRECTOR	DATE
-----------------------------------	------

Drawing Title  
SECOND FLOOR  
("WARD B") HVAC  
DEMOLITION PLAN

Project Title  
RENOVATION OF BLDG #1,  
2ND FLOOR, B-WARD

Date	JULY 2, 2010 (UPDATED 10/07/10)
Section No.	528
09-352 MD-201	



Department of Veterans Affairs