



PLUMBING FIXTURE SCHEDULE														
MARK	DESCRIPTION	WASTE PIPE		VENTPIPE		COLD WATER		HOT WATER		WASTE FIXTURE UNITS	WATER FIXTURE UNITS	LEAKY FIXTURES	ELECTRIC SENSOR	REMARKS
		IN	[mm]	IN	[mm]	IN	[mm]	IN	[mm]					
PP-101	WATER CLOSET FLOOR INTD	3	[173]	2	[591]	1/25	[191]			6	10	N/A	NO	BATHROOM  ELECTRIC SENSOR ONLY STAFF TOILET DRY
PP-103	WATER CLOSET WALL HANG	3	[173]	2	[591]	1/25	[191]			6	10	N/A	YES/NO	
PP-106	LAVATORY FLOOR CONTROL	3	[173]	1.6	[461]	0.6	[151]	0.6	[151]	3	3	YES	NO	
PP-113	LAVATORY FLOOR CONTROL	2	[191]	1.5	[381]	0.5	[131]	0.5	[131]	2	2	YES	NO	
PP-120	LAVATORY SENSOR CONTROL	2	[191]	1.5	[381]	0.5	[131]	0.5	[131]	2	2	NO	YES	
PP-142	SENSORLESS FLOOR MOUNTED	3	[173]	2	[591]	0.75	[181]	0.75	[181]	3	4	NO	NO	
PP-145	SENSORLESS FLOOR WALL MOUNT	3	[173]	2	[591]	1	[231]	0.75	[181]	3	4	YES	NO	
PP-146	SINK, SINK FLOOR, WALL MOUNT	3	[173]	2	[591]	1	[231]	0.75	[181]	3	4	YES	YES	
PP-154	KITCHEN SINK DOUBLE BOWL	3	[173]	2	[591]	1	[231]	0.75	[181]	3	4	NO	NO	
PP-158	SINK, SINK FLOOR	3	[173]	2	[591]	1	[231]	0.75	[181]	3	4	NO	NO	
PP-161	SHOWER	2	[191]	1.5	[381]	0.5	[131]	0.5	[131]	2	2	N/A	NO	
PP-163	TUB	2	[191]	1.5	[381]	0.5	[131]	0.5	[131]	2	2	N/A	NO	
FD-1	FLOOR DRAIN	3	[173]							3		N/A	N/A	
REFRIGERATOR														SELECTED BY ARCHITECT PROVIDE ALL REQUIRED PLUMBING CONNECTIONS
ICE MACHINE														SELECTED BY ARCHITECT PROVIDE ALL REQUIRED PLUMBING CONNECTIONS
WARNING TRANS														SELECTED BY ARCHITECT PROVIDE ALL REQUIRED PLUMBING CONNECTIONS
DRAINWATER														SELECTED BY ARCHITECT PROVIDE ALL REQUIRED PLUMBING CONNECTIONS, HOT WATER WASH AND HOT WATER FINAL RISE

PACKAGED REVERSE OSMOSIS SCHEDULE									
MARK	LOCATION	AREA AND/OR BLDG SERVED	SYSTEM AND/OR SERVICE	TYPE	PUMP ELECTRICAL				REMARKS
					POWER		PHASE	VOLT	
					AMPS	BREAKER AMPS			
1 FLOWS	2ND FLOOR MECHROOM	WARD B	COLD WATER	MULTISTAGE SINGLE PASS	12	20	1	208/220V	SEE NOTES ON THIS DRAWING

MEDICAL GAS ALARM PANEL SCHEDULE				
LOCATION	TYPE OF PANEL	GAGES	SERVICE INDICATOR LIGHTS	
PATIENT AREAS	AREA (ZONE) ALARM PANEL	YES	OVERLINE PRESSURE, MANUAL MEDICAL VACUUM PRESSURE, MEDICAL VACUUM LINE VACUUM LOW TEST BUTTON	

  

REVERSE OSMOSIS SYSTEM NOTES	
NO STEEL	PRODUCE WATER, 1.6 GPM AT 7°C AND 50% RECOVERY, AND SHALL INCLUDE THE FOLLOWING: 2.5 KW, 400 LOW ENERGY, HIGH REJECTION MEMBRANES IN 225 PSI RATED PVC VESSELS. EFFICIENCY MOTOR (11-1485), 208-220 V/1, GAGES FOR FEED FILTER AND VESSEL AHEAD IN AND OUT AND SS CASE, BRONZE MICROPROCESSOR SYSTEM CONTROLLER WITH PRODUCT TDS MONITORING AND ALARM LOW FEED PRESSURE PROTECTION SWITCH, BRAIN PRODUCT AND PROTECTION FLOW MONITORING, BRAIN AND PROTECTION FLOW MONITORING, 220V, TO MONITOR FEED FILTER HOUSING AND CARTRIDGE REPLACEMENT, FLUSH ON TANK FILL, FRESH DRAINAGE SETTABLE BY CONTROLLER. FRAME IS STAINLESS STEEL WELDED CONSTRUCTION.
AUTOMATIC BACKWASHING CARBON FILTER	FOR THE FEED WATER TO THE FEED WATER TO THE RO, 10" X 40" DEPT FRP TANK, 10" X 40" DEPT FRP TANK, 3/4" FIP INLET AND OUTLET, 1/2" OC DRAIN PORT RE-TRACIT LOOKOUT SWITCH.
ATMOSPHERIC PRODUCT STORAGE TANK	FOR STORAGE OF R.O. PRODUCT WATER, 10" X 40" X 20" GALVANNE COATING, COLORED BLACK, HOULE, 10" X 40" X 20" GALVANNE COATING, COLORED BLACK, HOULE, FITTED WITH INLET AND DRAIN VALVE.
FLOAT SWITCH	FOR R.O. SYSTEM CONTROL BY TANK LEVEL.
BESTER FILTRER	FROM STORAGE TANK AND DELIVERS TO END USAGE, POWER IS 208-220 VAC, 1-PHASE, MOTOR IS 1 HP, PUMP HAS INTEGRAL SWITCH FOR 40/60 PSI OUTPUT CONTROL AND INTEGRAL LOW FEED WATER PROTECTION SWITCHING.
5000 SYSTEM (MOUNTS ALL EQUIPMENT EXCEPT WATER STORAGE TANK)	5000 SHALL BE CONSTRUCTED WITH WELDED STEEL AND POWER COATED AND MOUNTED ON LEVELERS.

[illegible]


  

VA WESTERN NEW YORK HEALTHCARE SYSTEM 3495 BAILEY AVENUE BUFFALO, NEW YORK 14215	<p>BUFFALO, NY., 77 GOODELL ST 716-856-5636</p>
--	---

  

	<b>CARDIOLOGY</b>	<b>DATE</b>	<b>ENGINEERING MANAGER</b>	<b>DATE</b>
	<b>INFECTION CONTROL</b>	<b>DATE</b>	<b>CARELINE MANAGER</b>	<b>DATE</b>
	<b>SAFETY OFFICER</b>	<b>DATE</b>	<b>CHIEF OF STAFF</b>	<b>DATE</b>

  

<b>Drawing Title</b>	<b>Project Title</b>	<b>Date</b>
PLUMBING SCHEDULES	RENOVATION OF BLDG #1, 2ND FLOOR, B-WARD	JULY 2, 2010 (UPDATED 10/07/10)

  

MEDICAL CENTER DIRECTOR	Building Number <div style="border: 1px solid black; padding: 2px;">1</div>	Checked <div style="border: 1px solid black; width: 50px; height: 20px; margin-top: 2px;"></div>
ASSOCIATE MEDICAL CENTER DIRECTOR	Location V.A.M.C. BATAVIA, NEW YORK	Drawn <div style="border: 1px solid black; width: 50px; height: 20px; margin-top: 2px;"></div>

  

09-352 PL-501

  

Office of Facilities

Department of Veterans Affairs