



1/2" C-D SHEATHING W/ 10d AT 6" O.C. AT EDGES & 12" O.C. IN FIELD

- A. VERIFY ALL ELEVATION HEIGHTS AND DIMENSIONS W/ ARCHITECT AND FIELD.
- B. DECKING SUPPORT WELDS TO BE SEAM (BUTTON PUNCH).
- C. FINISHED FIRST FLOOR ASSUMED TO BE 100'-0".
- D. RE. S3.2-2 TYPICAL BEAM-BEAM AND BEAM-COLUMN CONNECTION.
- E. SAVE THE BRICK FROM THE (E) BLDG. WINDOW DEMO WHERE (N) ELEVATOR TOWER ATTACHES. CM/ ARCH.
- F. HEADER CONNECTION PER S3.1-16.
- G. RE. S3.2-20 FOR BRICK VENEER SUPPORT AT WINDOWS AND ALONG WALL CM/ ARCH. FOR WALL LOGGINGS.
- H. COLD FORMED STEEL FRAMING TO BE 600S200-54 AT 16" O.C. W/ ARCH FOR CONNECTIONS. CM/ ARCH FOR LOCATIONS.

1. 4. 1/2" CONC. OVER 20 GA. VEROO TYPE B DECKING, TYP. S3.1-10 & S3.2-3.
2. HSS 6x6x1/4 COL. TYP.
3. TYP. HSS 8x6x1/4 BEAMS.
4. STAIR STRINGER ATTACHMENT, RE. S3.1-8.
5. STEEL CANOPY BELOW, RE. S3.3-7.
6. (N) SECOND FLOOR JOISTS 14" TJI I30 JOISTS @ 16" O.C.
7. 3/4" T&G FLOOR SHEATHING W/ 10d AT 6" OC. AT EDGES AND 12" O.C. IN FIELD.
8. (E) FLOOR FRAMING.
9. (E) PORCH COVER SHORED DURING CONSTRUCTION.
10. (N) ROOF FRAMING: 11 7/8" TJI L65 @ 16" O.C.
11. 5/8" C-D SHEATHING W/ 10d AT 6" OC. AT EDGES AND 12" O.C. IN FIELD.
12. (E) FLOOR JOISTS.
13. S1623A STRAPS @ ENDS.
14. L514A STRAPS @ ENDS.
15. M51C28 STRAPS @ ENDS.
16. 1 1/2" VEROO 22 GA HSB-36 DECKING AT CANOPY, CW/ ARCH.



SCALE: $1/8'' = 1'-0''$



SCALE: $1/8" = 1'-0"$

DATE	DESCRIPTION