

2CLC Doors

Install UL listed, fire rated panic hardware suitable for a 1 hour fire doors. Hardware shall be surface mounted vertical rod locking devices. New hardware shall be integrated to function with existing automatic door opener, patient egress system, simplex access control system, and simplex fire alarm system. The new locking devices shall normally be unlocked and stay unlocked until the fire alarm is activated. Once the fire alarm is activated the power will be cut to the access control system and door opener such that the door will close and be mechanically latched via the new hardware. The contractor is responsible for making all door operations coordinate and operate as outlined above.

