

Wilkes-Barre VA Medical Center Fire Barrier Large Opening

2016.12.December / Basement / Area A -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
3/28/16	304579	1169	2016.12.December / Basement / Area A	Double Door	Large Opening	Joints	Gypsum	1 Hour	Previously under construction last inspection. 12 ft HOW
9/1/16	343255	1329	2016.12.December / Basement / Area A	CB11	Large Opening	Sections of walls	Gypsum	2 Hour	2.5X1.5 section of sheet rock missing DOD-3

2016.12.December / Floor 01 / Area A -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
3/28/16	306125	1168	2016.12.December / Floor 01 / Area A	N1-144	Large Opening	Large wall with	Concrete	1 Hour Smoke	7'x2' gypsum repair, studs already in place, dod:2 previously under construction last
6/10/16	325101	1290	2016.12.December / Floor 01 / Area A	Electrical room next to	Large Opening	Large wall with	Concrete	2 Hour	Deteriorating block with penetrations. 4ft x 2ft. DOD 10 due to mechanicals interfering.
6/10/16	325130	1291	2016.12.December / Floor 01 / Area A	C1-77	Large Opening	Large wall with	Concrete	Smoke Barrier	1.5ft x 1.5ft DOD 5. previously under renovation
6/10/16	325133	1292	2016.12.December / Floor 01 / Area A	C1-77	Large Opening	Large wall with	Concrete	Smoke Barrier	1.5ft x 1.5ft. DOD 5. previously under renovation
9/8/16	343846	1412	2016.12.December / Floor 01 / Area A	A1-31B	Large Opening	Sections of walls	Gypsum	1 Hour	1'x1' section of drywall missings, DOD4

2016.12.December / Floor 02 / Area A -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
6/8/16	324722	1274	2016.12.December / Floor 02 / Area A	Near double door. Atrium	Large Opening	Large wall with	Gypsum	1 Hour Smoke	Section of drywall missing. Not built of to deck. DOD 4

2016.12.December / Floor 03 / Area A-Reno 5/31/16 -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
6/7/16	324551	1256	2016.12.December / Floor 03 / Area A-Reno 5/31/16	C3-74	Large Opening	Sections of walls	Concrete	2 Hour	(2) 3ft x 4ft openings. Old elevator doors sealed with plywood an unrated material.
6/7/16	324620	1258	2016.12.December / Floor 03 / Area A-Reno 5/31/16	N3-69	Large Opening	Large wall with	Concrete	2 Hour	2ft x 2.5 ft Needs Block and Mortar Needs Penetrations Sealed
6/7/16	324702	1266	2016.12.December / Floor 03 / Area A-Reno 5/31/16	Blue Elevator Lobby	Large Opening	Joints	Gypsum	2 Hour	HOW 26ft x 1inch Needs Stuffed and Sprayed
6/7/16	324705	1267	2016.12.December / Floor 03 / Area A-Reno 5/31/16	A3-001	Large Opening	Joints	Gypsum	2 Hour	HOW 30ft x 3inches Already Stuffed Needs Sprayed
6/7/16	324706	1268	2016.12.December / Floor 03 / Area A-Reno 5/31/16	C3-17A	Large Opening	Joints	Gypsum	2 Hour	HOW 20ft x 1inch. previously under renovation
9/2/16	343356	1375	2016.12.December / Floor 03 / Area A-Reno 5/31/16	C3-119 and C3-61	Large Opening	Joints	Concrete	Smoke Barrier	30' HOW DOD-4
9/3/16	343441	1394	2016.12.December / Floor 03 / Area A-Reno 5/31/16	C3-64	Large Opening	Sections of walls	Gypsum	1 Hour	4x3 DOD 5
9/3/16	343442	1395	2016.12.December / Floor 03 / Area A-Reno 5/31/16	C3-64	Large Opening	Sections of walls	Gypsum	1 Hour	2x2 DOD 1

2016.12.December / Floor 04 / Area B -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
3/31/16	306557	1181	2016.12.December / Floor 04 / Area B	Break Room	Large Opening	Joints	Gypsum	1 Hour	10' HOW With multiple penetrations dod 2 Recently rentivated
3/31/16	306560	1184	2016.12.December / Floor 04 / Area B	Family Lounge-4-158	Large Opening	Joints	Gypsum	1 Hour	20' HOW with multiple penetrations DOD 4 recently rentivated
6/6/16	324253	1248	2016.12.December / Floor 04 / Area B	4-122	Large Opening	Joints	Gypsum	1 Hour	4ft x 3inches DOD 2 Needs Stuffed and Sealed
9/1/16	343181	1342	2016.12.December / Floor 04 / Area B	Storage left of 4-139	Large Opening	Sections of walls	Gypsum	1 Hour	10ft x 3ft DOD 10 Very difficult to install drywall due to mechanicals in the way

Client: Wilkes-Barre VA Medical Center
 1111 East End Blvd
 Wilkes-Barre, PA 18711

Report: Fire Barrier Wall-Large Opening Repair
 244-14C-0117

9/1/16	343204	1353	2016.12.December / Floor 04 / Area B	Double Door by 4-141	Large Opening	Sections of walls	Gypsum	Smoke Barrier	Smoke Barrier wall is not built to deck 8ft x 4ftft DOD 8 Very Difficult due to
--------	--------	------	---	-------------------------	------------------	----------------------	--------	------------------	--

2016.12.December / Floor 07 -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
6/3/16	324412	1240	2016.12.December / Floor 07	C7-49	Large Opening	Sections of walls	Concrete	2 Hour	(2) 3ft x 4ft openings. Old elevator shaft. Needs sealed.

2016.12.December / Floor 08 -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
6/2/16	323775	1234	2016.12.December / Floor 08	C8-33	Large Opening	Joints	Concrete	1 Hour	HOW 10ft x 4inches
8/30/16	341247	1317	2016.12.December / Floor 08	C8-21	Large Opening	Joints	Gypsum	2 Hour	8ft x 3inches Needs Stuffed and Sealed

2016.12.December / Floor 11 -

Date Created	EOCS ID #	Punch #	Full Plan View	Room Number	Item	Type	Wall Material	Fire Rating	Comments
6/1/16	323712	1215	2016.12.December / Floor 11	C11-22	Large Opening	Sections of walls	Concrete	2 Hour	Section of block missing. Not sealed up to deck. Needs block and mortar on all sides.