

## Attachment A: Interim Life Safety Measures Assessment for Scheduled Construction Activities

Directions: 1) Check 'Yes' or 'No' for Construction Life Safety Hazard Items #1 through #4 2) Check Appropriate ILSM for each column Marked as 'Yes'

Project Name and Number: Genomics 660-334

Construction Life Safety Hazard (#1 thru #4):	<b># 1.</b> <b>YES</b> <input checked="" type="radio"/> <b>NO</b> <b>Fire Alarm System impaired.</b>	<b># 2.</b> <b>YES</b> <input checked="" type="radio"/> <b>NO</b> <b>Sprinkler System impaired.</b>	<b># 3.</b> <b>YES</b> <input checked="" type="radio"/> <b>NO</b> <b>Egress / Exits Impaired.</b>	<b># 4.</b> <b>YES</b> <input checked="" type="radio"/> <b>NO</b> <b>Separation between construction and non-construction space has been degraded / altered.</b>
	<b>YES</b> <b>NO</b> <b>Fire Alarm System out of service more than 8 hours in 24 hour period.</b>	<b>YES</b> <b>NO</b> <b>Sprinkler System out of service more than 10 hours in 24 hour period.</b>		
<b>ILSMs:</b>				
<b>Temporary Fire Alarm and Detection Systems</b> Provide temporary but equivalent fire alarm and detection systems for use when a fire system is impaired. The organization determines when these systems are needed.				
<b>Provide Additional Firefighting Equipment</b> Provide additional firefighting equipment. The organization determines when to provide this equipment.				
<b>Post Signage</b> - Post signage identifying the location of alternative exits to everyone affected.				
<b>Inspect Exits</b> - Inspects exits in affected areas on a daily basis. The organization determines when these inspections are needed.				

## Attachment A: Interim Life Safety Measures Assessment for Scheduled Construction Activities

<b>Temporary Construction Partition Construction</b> - Use temporary construction partitions that are smoke-tight, or made of noncombustible or limited-combustible material that will not contribute to the development or spread of fire. The organization determines when to use these partitions.				X
<b>Fire Watch</b> - Increases surveillance of buildings, grounds, and equipment, giving special attention to construction areas and storage, excavation, and field offices. The organization determines when to increase surveillance.				
<b>Reduction Combustible Loads</b> - Enforces storage, housekeeping, and debris-removal practices that reduce the building's flammable and combustible fire load to the lowest feasible level. The organization determines when these practices are needed.				
<b>Firefighting Equipment Training</b> - Provide additional training to those who work in the organization on the use of firefighting equipment. The organization determines when to provide additional training.				

**Attachment A: Interim Life Safety Measures Assessment for Scheduled Construction Activities**

<b>Education</b> - The organization conducts education to promote awareness of building deficiencies, construction hazards, and temporary measures implemented to maintain fire safety. The organization determines when this education is needed.				
<b>Situational Awareness Training</b> - The organization trains those who work in the organization to compensate for impaired structural or compartmental fire safety features. The organization determines when this training is needed.				
<b>Additional Fire Drill per Quarter</b> - The organization does the following: Conducts one additional fire drill per quarter. The organization determines when these additional fire drills are needed.				
<b>Monthly inspection Temporary Systems</b> - Inspects and tests temporary systems monthly. The completion date of the tests is documented. The organization determines when these inspections and tests are needed.				
<b>Fire Department Notification</b> - Notify fire department of system impairment.				

**Additional Assessment Notes:**

## Attachment A: Interim Life Safety Measures Assessment for Scheduled Construction Activities

Implementation: Which ILSM is being implemented and how? Be descriptive on procedures put in place and departments notified.

Barrier shall be maintained between the construction area and the existing structure.

Assessment Performed By:

Date:

Safety Officer Review:

*CLRL* Carlos L. Aguilar

Date:

9/15/16