


**RFI FORM**

**Contractor Name: Herman Construction Group**  
**Address: 2060 Wineridge Place, Escondido CA 92029**  
**Phone/Fax: (858) 277-7100 / (858) 277-2500**  
**Send to: cecil.nichols@va.gov**

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	600-CSI-101	<b>RFI NO.:</b>	023
<b>PROJECT NAME:</b>	MRI Renovation & Expansion	<b>DATE REQUESTED:</b>	04/13/2017
<b>SOLICITATION NO.:</b>	VA262-17-B-0095	<b>REFERENCE:</b>	
<b>DRAWING:</b>	AD100	<b>SPECIFICATION SECTION:</b>	028213
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible: Confirm if the entire interstitial area will be asbestos-abated for each of the four construction phases (to include removal and complete replacement of the structural steel fireproofing?)</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p>KAL Response 4/18/17: There is no interstitial area in Building 160, and the existing structure is wood. For location of asbestos, refer to the asbestos surveys that are included in the Design Narrative Final Submittal (dated 5/27/16) as Appendices B &amp; C.</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b> 		<b>DATE:</b> 04/24/2017	