




KEY NOTES:

- 1 FURRED OUT WALL.
- 2 NONSPRINKLERED ELECTRICAL EQUIPMENT ROOM PER SECTION 8.15.11.3 OF NFPA 13-2013 EDITION.

SYMBOLS LIST

- 3 HOUR FIREWALL
- 2 HOUR FIREWALL
- 1 HOUR FIREWALL
- 2 HOUR FIRE/SMOKEWALL
- 1 HOUR FIRE/SMOKEWALL
- 30 MINUTE SMOKE BARRIER
- SMOKE RESISTIVE HAZARDOUS AREA
- NON RATED SMOKE PARTITION
- NON-RATED SMOKE BARRIER (COMMUNICATING SPACE)
- NON-FIRE-RATED PARTITION
- SPRINKLER/FIRE ALARM ZONE
- MANUAL PULL STATION
- FIRE EXTINGUISHER

BUILDING 1 BASEMENT FLOOR



FULLY SPRINKLERED
MIXED OCCUPANCY

Revisions		Date	 <div>Tennessee Valley Health Care System—Nashville 1310 24th Avenue South Nashville, TN 37212</div>		Drawing Title BUILDING 1 BASEMENT FLOOR	Client Project No.	Contract No.	Project Title STATEMENT OF CONDITIONS	Designed By	Checked By	Drawn By	Date 09/30/16	Drawing No. SOC-1 Sht. 2 Of 7
FP&C Proj.#:		1999.01				Building No. 1	AutoCAD File Name SOC01-B		Location TENNESSEE VALLEY VA NASHVILLE, TENNESSEE	Scale: NO SCALE			