LEGEND

⊗	SPRINKLER
▭	2X2 LIGHT FIXTURE
⊘	CEILING SUPPLY
⊠	CEILING RETURN
– – – – – –	CUBICLE CURTAIN TRACK
–·–·–·–·–	CEILING LIFT TRACK

NOTES:
1. REPLACE DROP CEILING WITH NEW AS SHOWN, IN AREAS OPENING TO THE CORRIDOR, ALIGN THE NEW CEILING TO THE CORRIDOR CEILING AS SHOWN. MAINTAIN EXISTING LAYOUT ON SPRINKLER HEADS, LOCATIONS SHOWN ARE APPROXIMATE.
2. AIR SUPPLY AND RETURN REGISTERS ARE FOR EXISTING DUCTWORK, INTENTION IS ONLY TO ALIGN TO NEW CEILING GRID. REPLACE ALL REGISTERS IN ROOM H-010 TO MATCH NEW USED IN ROOMS RENOVATED.
3. SIZE ON ALL AIR SUPPLIES AND RETURNS TO MATCH EXISTING.
4. HEIGHT OF ALL DROP CEILINGS AND SOFFITS IS TO BE 8' - 6".
5. DEMOLISH EXISTING CEILING LIFT TRACKS, RETAIN CHARGER, CHARGER STATION, AND MOTOR. INSTALL NEW TRACK AT LOCATION SHOWN. DESIGN OF MOUNTING AND INSTALLATION TO BE BY MANUFACTURER APPROVED INSTALLER. INSTALLATION TO INCLUDE LOAD TEST. SUBMIT SHOP DRAWINGS FOR APPROVAL.
6. ALL DIMENSIONS SHOWN ARE APPROXIMATE, CONTRACTOR IS TO VERIFY IN FIELD.
7. MAINTAIN EXISTING SOFFIT CEILINGS AND CEILING MOUNTED FIXTURES IN ROOMS H013, H014, AND H015.
8. CENTER ALL SPRINKLER HEADS, SPEAKERS, AIR REGISTERS, AND OTHER DEVICES ON A CEILING TILE.
9. REINSTALL EXISTING CEILING MOUNTED SPEAKERS IN THEIR APPROXIMATE CURRENT LOCATION. PROVIDE ADDITIONAL ELECTRICAL WORK AS NECESSARY TO ALIGN TO NEW GRID.

10 CEILING IN THIS ROOM IS REMAIN AS IS.



		CONSULTANTS:	ARCHITECT/ENGINEERS:	NORTH:		APPROVED:	Drawing Title: REFLECTED CEILING PLAN, GROUND FLOOR, 1/4" = 1'	Project Title: PHYSICAL THERAPY PHASING
						APPROVED:		
						APPROVED:	Approved: Director , VAHVHCS:	Location: CASTLE POINT, NEW YORK
Contract Documents	2-20-2012				APPROVED:	APPROVED:	Approved: Chief of Engineering	Date: 12-15-2010 / Checked / Drawn: JEF
INITIAL DRAWING	12-15-2010							
Revisions:	Date:							

Project Number	Engineering Service
620A4-11-224	
Building(s) Number: 18D	
Drawing Number: 18-AS-2	Department of Veterans Affairs
SHEET 4 OF 28	

VA FORM 08-6231, OCT 1978