

## **Response to RFI's & Scope of Work Clarifications**

### **VA69D-17-B-0600 Install Elevators B406**

**RFI #1 :** In reference to Specification 09 06 00-4 Car Operating Panel, where could we obtain information on Material product KSS 140?

**Answer to RFI #1:** KSS-140 is the type of signaling elevator control panel including lighted, impaired brail and audible alerts. This is referenced to a Kone or equal product.

**RFI #2:** In reference to Specification 14 21 00-12 Item 2.1A 1c, is there a process of submitting data sheets to be a prior approved equal?

**Answer to RFI #2:** There is no official form for a "prior approved equal"; however the equal product must meet the same like specifications provided.

**RFI #3:** The ATT002 Drawings file appears to be only 56 pages, but shows 126 pages in the index. Are any drawings missing?

**Answer to RFI #3:** The original design document was created for replacement of Elevators in B402, B404, and B406. This project is for removal and replacement of elevators in B406 only, so the unnecessary drawings have been removed.